

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

WATER WELL REPORT

State of Washington Date Printed: **27-Mar-2006** Log No. **6406**
Construction / Decommission: Original Construction Notice **193391**

CURRENT
Notice of Intent No.: **W232681**
Unique Ecology Well I.D. No **APB702**
Water Right Permit Number:
OWNER: **GOTHAM, BROTHERS**

OWNER ADD **525 S. MAIN**
COLVILLE, WA 99114

Well Add **EVANS CUTOFF RD**
City: **Evans, WA 99126** County: **Stevens**
Location: **1/4 SE 1/4 Sec 12 T 37 R 38E EW**
Lat/Long: Lat Deg Lat Min/Sec
(s, t, r still) Long Deg Long Min/Sec
REQUIRED)
Tax Parcel No.: **SP 61-93 LOT 2**

PROPOSED USE: **DOMESTIC**

TYPE OF WORK: Owners's Well Number: (If more than one well) **1**
NEW WELL Method: **ROTARY**

DIMENSIONS Diameter of well: **6** inches
Drilled **60** ft. Depth of completed well **58** ft.

CONSTRUCTION DETAILS: Casing installed **WELDED**
Liner installed: **6** " Dia from **+2** ft. to **53** ft.
" Dia from ft. to ft. " Dia from ft. to ft.
" Dia from ft. to ft. " Dia from ft. to ft.

Perforations: **No** Used In:
Type of perforator used
SIZE of perforations in. b in.
Perforation from ft. to ft.
Perforation from ft. to ft.
Perforation from ft. to ft.

Screens: **Yes** K-Pac Location **52**
Manufacture's Name **JOHNSON**
Type: **SLOTTED** Model No **STAINLESS**
Diam. **5** slot size **.012** from **53** ft. to **58** ft.
Diam. slot size from ft. to ft.

Gravel/Filter packed: **No** Size of Gravel
Material placed fro ft. to ft.

Surface seal: **Yes** To what depth **22** ft.
Seal method: Material used in seal **BENTONITE**
Did any strata contain unusable water **No**
Type of water Depth of strata
Method of sealing strata off

PUMP: Manufacture's name
Type: H.P. **0**

WATER LEVELS Land-surface elevation above mean sea level: **0** ft.
Static level **22** ft. below top of well Date **03/23/2006**
Artesian Pressure lbs per square inch Date
Artesian water controlled by

WELL TESTS: Drawdown is amount water level is lowered below static level.
Was a pump test made **No** If yes, by whom
Yield gal/min with ft drawdown after
Yield gal/min with ft drawdown after
Yield gal/min with ft drawdown after
Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)
Time: Water Level Time: Water Level Time: Water Level

Date of test:
Bailer test gal/min ft drawdown after hrs.
Air test **20** gal/min w/ stem set at **57** ft. for **1** hours
Artesian flow gpm Date
Temperature of water Was a chemical analysis made **No**

CONSTRUCTION OR DECOMMISSION PROCEDURE
Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.


Material	From	To
CLAY BROWN	0	4
SAND COBBLES CLAY	4	22
SAND GRAVEL W/WATER	22	60

RECEIVED
APR 13 2006
DEPARTMENT OF ECOLOGY
EASTERN REGIONAL OFFICE

Notes:

Work starte **03/23/2006** Complete **03/23/2006**

WELL CONSTRUCTION CERTIFICATION:
I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

Driller Engineer Trainee
Name: **DAVID MEYER** License No.: **2427**
Signature: 
f trainee, Licensed driller is: License No.:
Licensed Driller Signature

Drilling Company:
NAME: **FOGLE PUMP & SUPPLY, INC.** Shop: **COLVILLE**
ADDRESS: **316 W. 5TH**
Colville, WA 99114
Phone: **509-684-2569** Toll Free: **800-533-6518**
E-Mail: **jrs@foglepump.com**
FAX: **509-684-3032** WEB Site: **www.foglepump.com**
Contractor's
Registration No.: **FOGLEPS095L4** Date Log Created: **03/27/200**