

WATER WELL REPORT

Notice of Intent **W165989**

Date Printed 31 Dec 2002

Unique Well I D No **AHB522**

Log No **28302 125550**

State of Washington

Water Right Permit Number

(1) OWNER **SCHWAGER LES** Address **1652 ADDY GIFFORD RD Addy WA 99101**

(2) LOCATION OF WELL County **STEVENS** NW 1/4 NE 1/4 Sec 31 T 33 R 40E WM

(2a) Street Address of well
Tax Parcel No

(3) PROPOSED USE **DOMESTIC**

(4) TYPE OF WORK Owners s Well Number 1
NEW WELL (If more than one well)
Method **ROTARY**

(5) DIMENSIONS Diameter of well 6 inches
Drilled 66 ft Depth of completed well **66** ft

(6) CONSTRUCTION DETAILS Casing installed **WELDED**
Liner installed **NONE** 6 Dia from +2 ft to 65 ft
Dia from ft to ft Dia from ft to ft

Perforations used? **No** Used In
Type of perforator used
SIZE of perforations in by in
Perforations from ft to ft
Perforations from ft to ft
Perforations from ft to ft

Screens **No** K Pac Location
Manufacture s Name
Type Model No
Diam slot size from ft to ft
Diam slot size from ft to ft

Gravel packed **No** Size of Gravel
Gravel placed from ft to ft

Surface seal **Yes** To what depth **19** ft
Seal method Material used in seal **BENTONITE**
Did any strata contain unusable water? **No**
Type of water Depth of strata
Method of sealing strata off

(7) PUMP Manufacture s name
Type **NONE** H P **0**

(8) WATER LEVELS Land surface elevation
above mean sea level **0** ft
Static level **10** ft below top of well Date **11/08/2002**
Artesian Pressure lbs per square inch Date
Artesian water controlled by

(9) WELL TEST Drawdown is amount water level is lowered below static level

Was a pump test made? **No** If yes by whom
Yield gal/min with ft drawdown after

Recovery data Test Date
Time Water Level Time Water Level Time Water Level

Bailer test gal/min ft drawdown after hrs
Air test **8** gal/min w/ stem set at **64** ft for **2** hours
Artesian flow gpm Date
Temperature of water Was a chemical analysis made **No**

(10) Well Log
Formation Describe by color character-size of material and structure Show thickness of aquifers and the kind and nature of the material in each stratum penetrated -Show at least one entry for each change in formation

Material	From	To
TOPSOIL	0	2
CLAY SAND GRAVEL	2	35
BROWN CLAY	35	42
BLUE CLAY	42	45
GRAY CLAY GRAVEL SAND	45	64
SAND GRAVEL	64	66
HARD GRAY CLAY OR ROCK	66	66

Notes
TOTAL GPM = 7.8

Work started **11/08/2002** Complete **11/08/2002**

WELL CONSTRUCTION CERTIFICATION
I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

RONALD HURN License No **2258**
(Driller/Licensed Engineer)

Trainee Name _____ License No _____
NAME **FOGLE PUMP & SUPPLY INC** Shop **COLVILLE**

ADDRESS **316 W 5TH**
Colville WA 99114

Phone **509 684 2569** Toll Free **800 533 6518**

E Mail

FAX **509 684 3032** WEB Site **www.foglepump.com**

[SIGNED] *Ronald Hurn* License No **2258**
(Driller/Licensed Engineer)

Contractor s
Registration No **FOGLEPS095L4** Date Log Created **12/23/02**

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.