

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

WATER WELL REPORT

State of Washington Date Printed 09 May 2003 Log No
 Construction/Decommission Original Construction 10103
 Construction Notice of Intent # 133353

CURRENT
 Notice of Intent No W163575
 Unique Ecology Well I D No AHK885
 Water Right Permit Number

OWNER WATSON DAVID
OWNER ADDR 64 BON JON VIEW WAY SEQUIM WA 98382
Well Street Address LIGHTNING CREEK RD
City Tonasket WA 98855 **County** OKANOGAN
Location NW 1/4 SE 1/4 Sec 6 T 37 R 30E EWM
Lat/Long Lat Deg Lat Min/Sec
 (s t r still Long Deg Long Min/Sec)
REQUIRED)
Tax Parcel No 3730062015

PROPOSED USE DOMESTIC	
TYPE OF WORK Owners s Well Number (If more than one well) 1 NEW WELL Method ROTARY	
DIMENSIONS Diameter of well 6 inches Drilled 460 ft Depth of completed well 460 ft	
CONSTRUCTION DETAILS	Casing installed WELDED
Liner installed	6 Dia from 15 ft to 238 ft
4 Dia from 8 ft to 460 ft	Dia from ft to ft
Dia from ft to ft	Dia from ft to ft
Perforations Yes Used In Liner Type of perforator used SKILL SAW SIZE of perforations 7 in by 1/8 in 135 Perforations from 220 ft to 460 ft Perforations from ft to ft Perforations from ft to ft	
Screens No K Pac Location Manufacture s Name Type Model No Diam slot size from ft to ft Diam slot size from ft to ft	
Gravel/Filter packed No Size of Gravel Material placed from ft to ft	
Surface seal Yes To what depth 18 ft Seal method Material used in seal BENTONITE Did any strata contain unusable water? No Type of water Depth of strata Method of sealing strata off	
PUMP Manufacture s name Type H P 0	
WATER LEVELS Land surface elevation above mean sea level 0 ft Static level 90 ft below top of well Date 04/30/2003 Artesian Pressure lbs per square inch Date Artesian water controlled by	
WELL TESTS Drawdown is amount water level is lowered below static level Was a pump test made? No If yes by whom? Yield gal/min with ft drawdown after Yield gal/min with ft drawdown after Yield gal/min with ft drawdown after <i>Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)</i> Time Water Level Time Water Level Time Water Level Date of test Bailer test gal/min ft drawdown after hrs Air test 3 gal/min w/ stem set at 460 ft for 1 hours Artesian flow gpm Date Temperature of water Was a chemical analysis made? No	

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation Describe by color character size of material and structure Show thickness of aquifers and the kind and nature of the material in each stratum penetrated Show at least one entry for each change in formation

Material	From	To
GRAVEL SAND BOULDERS	0	21
GRAVEL SAND COARSE/BROWN	21	73
SAND COARSE/BROWN	73	115
CEMENTED GRAVEL FINE BROWN SAND	115	231
DECOMPOSED QUARTZ WHITE/SOFT	231	275
FRACTURED W/TRACE WATER	275	280
QUARTZ WHITE/SOFT	280	305
FRACTURED W/WATER	305	310
SALT & PEPPER GRANITE MEDIUM	310	336
FRACTURED W/WATER	336	340
SALT & PEPPER GRANITE MEDIUM	340	430
CONTINUED	430	430

Notes

DEPT OF ECOLOGY
 Received
 JUN 05 2003
 CENTRAL REGION OFFICE

Work started 04/25/2003 Completed 04/30/2003

WELL CONSTRUCTION CERTIFICATION

I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards Materials used and the information reported are true to my best knowledge and belief

Driller Engineer Trainee

Name JON RICARD License No 2341
 Signature *Jon Ricard*

If trainee Licensed driller is License No

Licensed Driller Signature

Drilling Company
NAME FOGLE PUMP & SUPPLY INC Shop REPUBLIC
ADDRESS PO Box 456
 Republic WA 99166
 Phone 5097752878 Toll Free 8008453500
 E Mail wlb@foglepump.com
 FAX 5097750498 WEB Site www.foglepump.com

Contractor's
 Registration No FOGLEPS095L4 Date Log Created 05/09/2003