

WATER WELL REPORT

Notice of Intent W128016

Date Printed 31-Oct-2000

Unique Well I D No AFQ855

Log No 0 **82802**

State of Washington

Water Right Permit Number

- (1) OWNER **MATHEWS, RICHARD** Address **5 VISTA DR Republic, WA 99166**
- (2) LOCATION OF WELL County **FERRY** NE 1/4 NE 1/4 Sec 1 T 37 R 32 WM
- (2a) Street Address of well **VISTA DR**
Tax Parcel No
- (3) PROPOSED USE **DOMESTIC**
- (4) TYPE OF WORK Owners' Number of well
NEW WELL (If more than one well) **1**

Date 10/31/2000 Method **ROTARY**

- (5) DIMENSIONS Diameter of well **6** inches
Drilled **190** ft Depth of completed well **190** ft

- (6) CONSTRUCTION DETAILS Casing installed **WELDED**
- Liner installed **6** " Dia from **+2** ft to **185** ft
" Dia from " Dia from ft to ft
" Dia from ft to ft " Dia from ft to ft
- Perforations used? **No** Used In
- Type of perforator used
- SIZE of perforations in by in
- Perforations from ft to ft
Perforations from ft to ft
Perforations from ft to ft

Screens Yes K-Pac Location

Manufacture's Name **JOHNSON**

Type Model No

Diam **5** slot size **10** from **185** ft to **190** ft
Diam slot size from ft to ft

Gravel packed No Size of Gravel

Gravel placed from ft to ft

Surface seal Yes To what depth **18** ftSeal method Material used in seal **BENTONITE**Did any strata contain unusable water? **Yes**Type of water **CLAY** Depth of strata **184**Method of sealing strata off **6" CASING**

- (7) PUMP Manufacture's name
Type **HP** **0**

- (8) WATER LEVELS Land-surface elevation
above mean sea level **0** ft
- Static level **115** ft below top of well Date **08/30/2000**
- Artesian Pressure lbs per square inch Date
- Artesian water controlled by

- (9) WELL TESTS Drawdown is amount water level is lowered
below static level

Was a pump test made? **No** If yes, by whom

Yield gal/min with ft drawdown after

Recovery data

Time Water Level

Test Date

Bailer test gal/min ft drawdown after hrs

Air test **10** gal/min w/ stem set at **188** ft for **1** hours


Artesian flow gpm Date

Temperature of water Was a chemical analysis made **No**

(10) Well Log

Formation Describe by color character, size of material and structure Show thickness of aquifers and the kind and nature of the material in each stratum penetrated Show at least one entry for each change in formation

Material	From	To
CLAY BROWN GRAVEL	0	19
COBBLES	19	19
CLAY HARDPAN GRAY	19	182
CLAY SILT GRAY	152	184
W/WATER	184	184
SAND FINE BROWN	184	190
GRAVEL WATER	190	190



Notes

2' RISER ON TOP OF SCREEN

Work started **08/29/2000**Completed **08/30/2000**

WELL CONSTRUCTION CERTIFICATION

I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

JON RICARDLicense No **2341**

(Driller/Licensed Engineer)

Trainee Name

License No

NAME **FOGLE PUMP & SUPPLY, INC**Shop **COLVILLE**ADDRESS **316 W 5TH****Colville, WA 99114**Phone **509-684-2569**Toll Free **800-533-6518**

E-Mail

FAX **509-684-3032**WEB Site **www.foglepump.com**

[SIGNED]

License No **2341**

Contractor's

(Driller/Licensed Engineer)

Registration No **FOGLEPS095L4**Date Log Created **10/31/00**

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.