

# WATER WELL REPORT

State of Washington    Date Printed: 15-Dec-2014    Log No. \_\_\_\_\_  
 Construction / Decommission: Original    0  
 Construction    Construction Notice

CURRENT  
 Notice of Intent No.: WE19366  
 Unique Ecology Well I.D. No. BHW950  
 Water Right Permit Number:  
 OWNER: CRESPO, DAVID

**PROPOSED USE: DOMESTIC**

OWNER ADD PO BOX 207  
 ADDY, WA 99101

TYPE OF WORK: Owners's Well Number: (If more than one well)  
**NEW WELL**                      Method: **ROTARY**

Well Add 2644 ADDY GIFFORD RD  
 City: Addy, WA 99101                      County: Stevens  
 Location: SW 1/4 NW 1/4 Sec 33 T 33 R 38 EW  
 Lat/Long:                      Lat Deg                      Lat Min/Sec  
 (s, t, r still                      Long Deg                      Long Min/Sec  
 REQUIRED)  
 Tax Parcel No.: 1830450

**DIMENSIONS:** Diameter of well: 6 inches  
 Drilled 100 ft.                      Depth of completed well 100 ft.

CONSTRUCTION DETAILS:	Casing installed <b>WELDED</b>
Liner installed: PVC	6" Dia from +1.5 ft. to 27 ft.
4" Dia from 20 ft. to 100 ft.	" Dia from ft. to ft.
	" Dia from ft. to ft.

**CONSTRUCTION OR DECOMMISSION PROCEDURE**

Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

Perforations: Yes                      Used In:  
 Type of perforator used **SKILL SAW**  
 SIZE of perforations 1/8 in. by 7 in.  
 50 Perforations from 20 ft. to 100 ft.  
 Perforations from ft. to ft.  
 Perforations from ft. to ft.

Material	From	To
CLAY LOAM BRN W/GRAVELS	0	19
SHALE BLACK MED	19	55
FRAC/BROKEN W/9 GPM TOTAL	55	65
SHALE BLACK SOFT	65	100

Screens: 0    K-Pac Location:  
 Manufacture's Name  
 Type:                      Model No  
 Diam. slot size: from ft. to ft.  
 Diam. slot size: from ft. to ft.

## RECEIVED

JAN 20 2015

Department of Ecology  
 Eastern Washington Office

Gravel/Filter packed: No    Size of Gravel  
 Material placed fro ft. to ft.  
 Surface seal: Yes To what depth 27 ft.  
 Seal method: 6" CASING    Material used in seal BENTONITE  
 Did any strata contain unusable water No  
 Type of water                      Depth of strata  
 Method of sealing strata off

Notes:

**PUMP:**    Manufacture's name  
 Type:                      H.P.                      0

Work starts 10/08/2014                      Complete 10/09/2014

**WATER LEVELS**    Land-surface elevation above mean sea level: 0 ft.  
 Static level 15 ft.    below top of well Date 10/09/2014  
 Artesian Pressure lbs per square inch Date  
 Artesian water controlled by

**WELL CONSTRUCTION CERTIFICATION:**  
 I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

**WELL TESTS:** Drawdown is amount water level is lowered below static level.  
 Was a pump test made No    If yes, by whom  
 Yield: [ ] gal/min with [ ] ft drawdown after [ ]  
 Yield: [ ] gal/min with [ ] ft drawdown after [ ]  
 Yield: [ ] gal/min with [ ] ft drawdown after [ ]

Driller     Engineer     Trainee  
 Name: JON RICARD                      License No.: 2341  
 Signature:

Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)

Time: [ ]	Water Level [ ]	Time: [ ]	Water Level [ ]	Time: [ ]	Water Level [ ]
[ ]	[ ]	[ ]	[ ]	[ ]	[ ]
[ ]	[ ]	[ ]	[ ]	[ ]	[ ]

Date of test:  
 Bailer test                      gal/min                      ft drawdown after                      hrs.  
 Air test 9                      gal/min w/ stem set at 99 ft. for 1.5 hours  
 Artesian flow                      gpm                      Date  
 Temperature of water                      Was a chemical analysis made No

If trainee, Licensed driller is: \_\_\_\_\_ License No.: \_\_\_\_\_  
 Licensed Driller Signature \_\_\_\_\_

**Drilling Company:**  
 NAME: FOGLE PUMP & SUPPLY, INC.                      Shop: COLVILLE  
 ADDRESS: 316 W. 5TH  
                     Colville, WA 99114  
 Phone: 509-684-2569                      Toll Free: 800-533-6518  
 E-Mail: [jeanne@foglepump.com](mailto:jeanne@foglepump.com)  
 FAX: 509-684-3032                      WEB Site: [www.foglepump.com](http://www.foglepump.com)  
 Contractor's  
 Registration No.: FOGLEPS095L4    Date Log Created: 10/14/2014