ţ		
WATER WELL REPORT 0	43	805(
Original - Ecology, 1st copy - owner, 2nd copy - driller	CURRENT	,
Construction/Decommission ("x" in circle)	Notice of Intent No. WE13111	
Construction	Unique Ecology Well ID Tag No. BCE 679	
Decommission ORIGINAL INSTALLATION	Water Right Permit No.	
Notice of Intent Number	_	
PROPOSED USE: ☐ Domestic ☐ Industrial ☐ Municipal ☐ DeWater ☐ Irrigation ☐ Test Well ☐ Other	Property Owner Name Larry & Hollie Dra	<u>inge</u>
TYPE OF WORK: Owner's number of well (if more than one)	Well Street Address <u>591 Stateline Road</u>	
⊠ New well	City Newport County Pend Oreille	
DIMENSIONS: Diameter of well 6 inches, drilled 144 ft.	Location <u>SW</u> 1/4-1/4 <u>NW</u> 1/4 Sec <u>30</u> Twn <u>31</u> R <u>46</u>	EWM ⊠
Depth of completed well 144ft.	Lat/Long	Or WWM □
CONSTRUCTION DETAILS	(s, t, r Still Lat Deg Min Sec	_
Casing ⊠ Welded <u>6</u> " Diam. from ±1.5 ft. to <u>135.5</u> ft. Installed: ☐ Liner installed "Diam. from ft. to ft.	REQUIRED) Long Deg Min Se	
Installed:	Tax Parcel No. <u>463130060001</u>	
Perforations: Yes No		
Type of perforator used	CONSTRUCTION OR DECOMMISSION PROCE Formation: Describe by color, character, size of material and structure, and the	
SIZE of perfsin. byin. and no. of perfsfromft. toft. Screens: ☑ Yes ☐ No ☑ K-Pac Location 134'	material in each stratum penetrated, with at least one entry for each change o ADDITIONAL SHEETS IF NECESSARY.)	
Manufacturer's Name	MATERIAL	FROM TO
Type Stainless Steel Model No.	Topsoil	0 1
Diam. <u>5</u> Slot size <u>.020</u> from <u>135.5</u> ft. to <u>140.5</u> ft.	Sandy loam, fine brown	1 27
Diam. <u>5</u> Slot size <u>sump</u> from <u>140.5</u> ft. to <u>144</u> ft.	Gravel, course with sand Clay, soft brown & gray silt seams	27 47 47 110
Gravel/Filter packed: Yes No Size of gravel/sand	Clay, firm gray & medium fine sand seams	110 131
Materials placed fromft. toft.	Sand, medium fine & firm gray clay mix	131 134
Surface Seal: Yes No To what depth? 18 ft.	Sand, medium fine with some clay	134 141
Material used in seal Bentonite Did any strata contain unusable water? Yes ⊠ No	Clay, firm gray	141 144
Type of water? Depth of strata		
Method of sealing strata off		
PUMP: Manufacturer's Name		,
Type: H.P		
WATER LEVELS: Land-surface elevation above mean sea level ft.		ļ
Static level 113' ft. below top of well Date 9/9/11		-
Artesian pressure lbs. per square inch Date		
Artesian water is controlled by cap, valve, etc.)		
WELL TESTS: Drawdown is amount water level is lowered below static level		
Was a pump test made? Yes No If yes, by whom?		
Yield:gal/min. withft. drawdown afterhrs. Yield:gal/min. withft. drawdown afterhrs.	SEP 2 9 2011	
Yield:gal/min. withft. drawdown afterhrs. Recovery data (time taken as zero when pump turned off) (water level measured from well	DEPARTMENT OF LOOLOGY	
top to water level)	EASTERN RECIONAL OFFICE	
Time Water Level Time Water Level		
Date of test Bailer test gal./min. withft. drawdown afterhrs.		
Airtest 10 gal./min. with stem set at 135ft, for 2hrs.	Start Date 9/8/11 Comp	leted Date 9/9/11
Artesian flowg.p.m. Date	Comp	Total Date gist 11

WELL CONSTRUCTION CERTIFICATION: I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

☑ Driller ☐ Engineer ☐ Trainee Driller or trainee License No. 1719
Name (Print Last, First) Morgan Joy
Driller/Engineer/Trainee Signature
IF TRAINEE: Driller's License No:
Driller's Signature:

Was a chemical analysis made?

Yes

No

JOYCO DRILLING INC
509-292-2000 or 877-292-WELL (9355)
1813 Willms Road
Elk, WA 99009

Contractor's Registration No. JOYCOD1923M3

Date 9/20/11 M9/28

Temperature of water