

RECEIVED

WATER WELL REPORT



Type of Work:

Construction, Decommission, Original installation NOI No.

Proposed Use: Domestic, Industrial, Municipal, Dewatering, Irrigation, Test Well, Other

Construction Type: New well, Alteration, Deepening, Method: Driven, Jetted, Cable Tool, Dug, Air-, Mud-Rotary

Dimensions: Diameter of boring 6 in., to 384 ft., Depth of completed well 383 ft.

Table with columns: Casing, Liner, Diameter, From, To, Wall Thickness, Steel, PVC, Welded, Thread

Perforations: Yes/No, Type of perforator used, No. of perforations, Size of perforations, Perforated from ft. to ft. below ground surface

Screens: Yes/No, Manufacturer's Name JOHNSON, Type STAINLESS, Model No., Diameter 6 in., Slot size 16 in., from 378 ft. to 383 ft.

Sand/Filter pack: Yes/No, Size of pack material in., Materials placed from ft. to ft.

Surface Seal: Yes/No, To what depth? 18 ft., Material used in seal BENTONITE, Did any strata contain unusable water? Yes/No, Type of water?, Depth of strata, Method of sealing strata off

Pump: Manufacturer's Name, Type, H.P., Pump intake depth: ft., Designed flow rate: gpm

Water Levels: Land-surface elevation above mean sea level ft., Stick-up of top of well casing ft. above ground surface, Static water level 110 ft. below top of well casing Date 07/21/2020, Artesian pressure lbs. per square inch, Date, Artesian water is controlled by (cap, valve, etc.)

Well Tests: Was a pumping test performed? No/Yes by whom?, Yield gpm with ft. drawdown after hrs., Recovery data (time = zero when pump is turned off - water level measured from well top to water level), Date of pumping test, Bailer test gpm with ft. drawdown after hrs., Air test 25+ gpm with stem set at 380 ft. for 1 hrs., Date 07/21/2020, Artesian flow gpm, Temperature of water °F, Was a chemical analysis made? Yes/No

WELL CONSTRUCTION CERTIFICATION: I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

Driller Trainee PE - Print Name JOE DUNKIN, Signature, License No. 3280, IF TRAINEE: Sponsor's License No., Sponsor's Signature

Notice of Intent No. WE39643, Unique Ecology Well ID Tag No. BMH547, AUG 03 2020

Site Well Name (if more than one well): Department of Ecology Eastern Washington Office, Water Right Permit/Certificate No., Property Owner Name BRADLEY OWEN

Well Street Address 3339 HIGHWAY 25 NORTH #48

City NORTHPORT County STEVENS

Tax Parcel No. 0619118

Was a variance approved for this well? Yes/No

If yes, what was the variance for?

Location (see instructions on page 2): WWM or EWM, SE 1/4-1/4 of the NW 1/4; Section 32 Township 39 Range 39

Latitude (Example: 47.12345)

Longitude (Example: -120.12345)

Driller's Log/Construction or Decommission Procedure

Formation: Describe by color, character, size of material and structure, and the kind and nature of the material in each layer penetrated, with at least one entry for each change of information. Use additional sheets if necessary.

Table with columns: Material, From, To. Rows include SAND BROWN, SAND GRAVEL, SAND GRAVEL BOULDERS, SAND BROWN, CLAY BROWN, CLAY GRAY, CLAY SAND GRAY, SAND FINE, SAND MEDIUM, SAND GRAVEL, SAND FINE.

Start Date 07/15/2020 Completed Date 07/21/2020

Drilling Company FOGL E PUMP & SUPPLY, INC., Address 2250 NORTH HIGHWAY, City, State, Zip COLVILLE, WA 99114, Contractor's, Registration No. FOGLEPS095L4, Date 07/21/2020

The Department of Ecology does NOT warranty the Data and/or information on this well report.