

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

WATER WELL REPORT

State of Washington Date Printed: **03-May-2006** Log No. **10606**
 Construction / Decommission: Original Construction Notice **194658**
Construction

CURRENT
 Notice of Intent No.: **W232671**
 Unique Ecology Well I.D. No **APB735**
 Water Right Permit Number:
 OWNER: **GOFF, FERRIS**

PROPOSED USE: DOMESTIC

OWNER ADD **2776 - A DEEP LAKE BOUNDARY RD**
COLVILLE, WA 99114

TYPE OF WORK: Owners's Well Number: (If more than one well) **1**
NEW WELL Method: **ROTARY**

Well Add **2776 - A DEEP LK BOUNDARY**
 City: **Colville, WA 99114** County: **Stevens**
 Location: **S 1/4 NW 1/4 Sec 34 T 39 R 41E EW**
 Lat/Long: Lat Deg Lat Min/Sec
 (s, t, r still REQUIRED) Long Deg Long Min/Sec
 Tax Parcel No.:

DIMENSIONS Diameter of well: **6** inches
 Drilled **60** ft. Depth of completed well **58** ft.

CONSTRUCTION DETAILS: Casing installed **WELDED**
 Liner installed: **6** " Dia from **+2** ft. to **53** ft.
 " Dia from ft. to ft. " Dia from ft. to ft.

CONSTRUCTION OR DECOMMISSION PROCEDURE
 Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

Perforations: **No** Used In:
 Type of perforator used
 SIZE of perforations in. b in.
 Perforation from ft. to ft.
 Perforation from ft. to ft.
 Perforation from ft. to ft.

Material	From	To
COBBLES GRAVEL CLAY	0	34
CLAY SAND WET	34	46
GRAVEL W/SAND W/WATER	46	60

Screens: **Yes** K-Pac Location **52**
 Manufacture's Name **JOHNSON**
 Type: **SLOTTED** Model No **STAINLESS**
 Diam. **5** slot size **.012** from **53** ft. to **58** ft.
 Diam. slot size from ft. to ft.

RECEIVED

MAY - 5 2006

DEPARTMENT OF ECOLOGY
 EASTERN REGIONAL OFFICE

Gravel/Filter packed: **No** Size of Gravel
 Material placed fro ft. to ft.

Surface seal: **Yes** To what depth **34** ft.
 Seal method: Material used in seal **BENTONITE**
 Did any strata contain unusable water **No**
 Type of water Depth of strata
 Method of sealing strata off

Notes:


PUMP: Manufacture's name
 Type: H.P. **0**

Work starte **04/18/2006** Complete **04/19/2006**

WATER LEVELS Land-surface elevation above mean sea level: **0** ft.
 Static level **34** ft. below top of well Date **04/19/2006**
 Artesian Pressure lbs per square inch Date
 Artesian water controlled by

WELL CONSTRUCTION CERTIFICATION:
 I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.
 Driller Engineer Trainee

WELL TESTS: Drawdown is amount water level is lowered below static level.
 Was a pump test made **No** If yes, by whom
 Yield gal/min with ft drawdown after
 Yield gal/min with ft drawdown after
 Yield gal/min with ft drawdown after

Name: **DAVID MEYER** License No.: **2427**
 Signature: 
 f trainee, Licensed driller is: _____ License No.: _____
 Licensed Driller Signature _____

Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)

Time:	Water Level	Time:	Water Level	Time:	Water Level
<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>
<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>	<input type="text"/>

 Date of test:
 Bailer test gal/min ft drawdown after hrs.
 Air test **50** gal/min w/ stem set at **51** ft. for **1** hours
 Artesian flow gpm Date
 Temperature of water Was a chemical analysis made **No**

Drilling Company:
 NAME: **FOGLE PUMP & SUPPLY, INC.** Shop: **COLVILLE**
 ADDRESS: **316 W. 5TH**
Colville, WA 99114
 Phone: **509-684-2569** Toll Free: **800-533-6518**
 E-Mail: **jrs@foglepump.com**
 FAX: **509-684-3032** WEB Site: **www.foglepump.com**
 Contractor's
 Registration No.: **FOGLEPS095L4** Date Log Created: **05/03/200**