

WATER WELL REPORT

Start Card No. W074320

53334

STATE OF WASHINGTON

Unique Well I.D. # ACK873

Water Right Permit No.

(1) OWNER: Name SISYPHUS-KINSEY, ELAINE Address PO BOX 1467 ORIENT, WA 99160-

(2) LOCATION OF WELL: County STEVENS W 1/2 E 1/2 Lot 2 - 1/4 1/4 Sec 31 T 40 N., R 37R WM

(2a) STREET ADDRESS OF WELL (or nearest address) 3610 SAND CREEK ROAD,

(3) PROPOSED USE: DOMESTIC

(4) TYPE OF WORK: Owner's Number of well 1
(If more than one)
NEW WELL Method: ROTARY(5) DIMENSIONS: Diameter of well 6 inches
Drilled 198 ft. Depth of completed well 198 ft.(6) CONSTRUCTION DETAILS:
Casing installed: 6 " Dia. from +1 ft. to 193 ft.
WELDED " Dia. from ft. to ft.
" Dia. from ft. to ft.

Perforations: NO

Type of perforator used

SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: NO

Manufacturer's Name

Type Model No.
Diam. slot size from ft. to ft.
Diam. slot size from ft. to ft.

Gravel packed: NO

Gravel placed from ft. to ft.

Surface seal: YES To what depth? 18 ft.

Material used in seal BENTONITE

Did any strata contain unusable water? NO

Type of water? Depth of strata ft.

Method of sealing strata off CASING

(7) PUMP: Manufacturer's Name
Type NONE H.P.(8) WATER LEVELS: Land-surface elevation
above mean sea level ... ft.
Static level 8 ft. below top of well Date 10/07/96
Artesian Pressure lbs. per square inch Date
Artesian water controlled by CAP

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.

Was a pump test made? NO If yes, by whom?
Yield: gal./min with ft. drawdown after hrs.

Recovery data

Time Water Level Time Water Level Time Water Level

Date of test / /

Bailer test gal/min. ft. drawdown after hrs.

Air test 2.5-3 gal/min. w/ stem set at 193 ft. for 1 hrs.


Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? NO

(10) WELL LOG

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

MATERIAL	FROM	TO
DIRT SAND	0	8
COMPACTED SILT BROKEN ROCK	8	90
SILT BROKEN ROCK	90	115
COMPACTED SILT BROKEN ROCK	115	193
BLACK LIMESTONE	193	198
	198	



Work started 10/03/96

Completed 10/07/96

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME FOGLE PUMP & SUPPLY, INC.

(Person, firm, or corporation) (Type or print)

ADDRESS 316 W 5TH

[SIGNED] Terry D. Corbitt License No. 1895

Contractor's

Registration No. FOGLEPS095L4

Date 11/19/96