

POFF PUMP AND SUPPLY, INC  
PUMP TEST RESULTS

NAME: David Baker DATE: MAY 18, 1992  
 ADDRESS: 738 Applegate Colville, WA  
 WELL TYPE: Domestic DEPTH: \_\_\_\_\_ STATIC: \_\_\_\_\_  
 Drilled: X casing size: 6" Steel Casing  
 Dug: \_\_\_\_\_ casing size: \_\_\_\_\_  
 PUMP TYPE: Berkeley Submersible HP: 1/2 HP 120V SETTING: \_\_\_\_\_  
 TANK SIZE & BRAND: Well x Trol 40 gal Bladder  
 LEGAL DESCRIPTION: \_\_\_\_\_ SEC: \_\_\_\_\_ TWP: \_\_\_\_\_ RNG: \_\_\_\_\_

START TIME:	GPM	Description
1) 1:30 PM	5 gal/min	Cold & Clear
2) 1:45 PM	5 gal/min	Cold & Clear
3) 2:00 PM	5 gal/min	Cold & Clear
4) 2:15 PM	5 gal/min	Cold & Clear
5) 2:30 PM	5 gal/min	Cold & Clear
6) 2:45 PM	5 gal/min	Cold & Clear
7) 3:00 PM	3 gal/min	Cold & Clear
8) 3:05 PM	2 gal/min	Cloudy
9) 3:08 PM	broke suction	Cloudy/Orange
10) 3:15 PM	2 gal/min	
11) Pumped about 16 gallons & broke suction		Rusty water
12)		
13)		
14)		
15)		
16)		
17)		

This well seems to produce about 2-3 gallons a minute

Thanks  
David Baker