

# WATER WELL REPORT

State of Washington Date Printed: 06-Nov-2006 Log No. 41306  
 Construction / Decommission: Original Construction Notice 208411

<b>PROPOSED USE: DOMESTIC</b>																											
<b>TYPE OF WORK:</b> Owners's Well Number: (If more than one well) 1 <b>NEW WELL</b> Method: <b>ROTARY</b>																											
<b>DIMENSIONS</b> Diameter of well: 6 inches Drilled 320 ft. Depth of completed well 320 ft.																											
<b>CONSTRUCTION DETAILS:</b>		Casing installed <b>WELDED</b>																									
Liner installed: <b>PVC</b>		6 " Dia from +2 ft. to 18 ft.																									
4 " Dia from 10 ft. to 320 ft.		" Dia from ft. to ft.																									
<b>Perforations:</b> Yes Used in: Liner Type of perforator used <b>SKILL SAW</b> SIZE of perforations 6 in. b 1/8 in. 100 Perforation from 140 ft. to 320 ft. Perforation from ft. to ft. Perforation from ft. to ft.																											
<b>Screens:</b> No K-Pac Location Manufacture's Name Type: Model No Diam. slot size from ft. to ft. Diam. slot size from ft. to ft.																											
<b>Gravel/Filter packed:</b> No Size of Gravel Material placed from ft. to ft.																											
<b>Surface seal:</b> Yes To what depth 18 ft. Seal method: Material used in seal <b>BENTONITE</b> Did any strata contain unusable water No Type of water Depth of strata Method of sealing strata off																											
<b>PUMP:</b> Manufacture's name Type: H.P. 0																											
<b>WATER LEVELS</b> Land-surface elevation above mean sea level: 0 ft. Static level 60 ft. below top of well Date 08/24/2006 Artesian Pressure lbs per square inch Date Artesian water controlled by																											
<b>WELL TESTS:</b> Drawdown is amount water level is lowered below static level. Was a pump test made No If yes, by whom Yield gal/min with ft drawdown after Yield gal/min with ft drawdown after Yield gal/min with ft drawdown after Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level) <table border="1"> <tr> <td>Time:</td> <td>Water Level</td> <td>Time:</td> <td>Water Level</td> <td>Time:</td> <td>Water Level</td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> <tr> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> </tr> </table> Date of test: Bailer test gal/min ft drawdown after hrs. Air test 3-4 gal/min w/ stem set at 319 ft. for .1 hours Artesian flow gpm Date Temperature of water Was a chemical analysis made No				Time:	Water Level	Time:	Water Level	Time:	Water Level																		
Time:	Water Level	Time:	Water Level	Time:	Water Level																						

## CURRENT

Notice of Intent No.: W232589

Unique Ecology Well I.D. No APQ199

Water Right Permit Number:

OWNER: KOSTURA, JOHN

OWNER ADD 617 NORTH 192ND AVE  
 BUCKEYE, AZ 85326

Well Add 3389 MOORE ROAD

City: Northport, WA 99157

County: Stevens

Location: NW 1/4 SW 1/4 Sec 26 T 39 R 38E EW

Lat/Long:

Lat Deg

Lat Min/Sec

(s, t, r still

Long Deg

Long Min/Se

REQUIRED)

Tax Parcel No.:

## CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

Material	From	To
TOP SOIL	0	3
SHALE GRAY SOFT	3	18
LIMESTONE GRAY MEDIUM	18	40
LIMESTONE BROWN MEDIUM	40	60
LIMESTONE GRAY MED. W/TRACE	60	200
LIMESTONE BROWN MEDIUM TO SOFT	200	280
LIMESTONE BROWN/GRAY W/FRACS W/WATER	280	320

NOV 16 2006

## Notes:

TRACE WATER 160'

Work starts 08/23/2006

Complete 08/24/2006

## WELL CONSTRUCTION CERTIFICATION:

I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

☒ Driller ☐ Engineer ☐ Trainee

Name: RONALD HURN License No.: 2258

Signature:

If trainee, Licensed driller is:

License No.:

Licensed Driller Signature

## Drilling Company:

NAME: FOGLE PUMP & SUPPLY, INC.

Shop: COLVILLE

ADDRESS: 316 W. 5TH

Colville, WA 99114

Phone: 509-684-2569

Toll Free: 800-533-6518

E-Mail: jeanne@foglepump.com

FAX: 509-684-3032

WEB Site: www.foglepump.com

Contractor's

Registration No.: FOGLEPS095L4

Date Log Created: 10/25/2006