

WATER WELL REPORT

State of Washington Date Printed: **24-Mar-2005** Log No. **4505**
Construction/Decommission Original **Construction** Construction Notice

CURRENT

Notice of Intent No.: **W182162**
Unique Ecology Well I.D. No **AKM439**
Water Right Permit Number:

171943

OWNER: **RAY, JERRY**

OWNER ADDR: **5618 W. CHARLENE CT SPOKANE, WA 99208**

Well Street Address: **ORCHARD DRIVE**

City: **Evans, WA 99126**

County: **STEVENS**

Location: 1/4 1/4 Sec 22 T 37 R 38E EW
Whitefield Bay 1st Lot #9 TAX 16
Lat Long: Lat Deg Lat Min/Sec
(s, t, r still)

REQUIRED) Long Deg Long Min/Sec

Tax Parcel No.: **620500**

PROPOSED USE: DOMESTIC	
TYPE OF WOR	Owners's Well Number: (If more than one well) 1
NEW WELL	Method: ROTARY
DIMENSIONS Diameter of well: 6 inches Drilled 220 ft. Depth of completed well 220 ft.	
CONSTRUCTION DETAILS:	
Casing installed WELDED	
Liner installed:	6 " Dia from +2 ft. to 110 ft. " Dia from ft. to ft. " Dia from ft. to ft.
4 " Dia from 20 ft. to 220 ft.	
Perforations: Yes Used In: Liner Type of perforator used SKILL SAW SIZE of perforations 6 in. b 1/8 in. 110 Perforation from 120 ft. to 220 ft. Perforation from ft. to ft. Perforation from ft. to ft.	
Screens: No K-Pac Location Manufacture's Name Type: Model No Diam. slot size from ft. to ft. Diam. slot size from ft. to ft.	
Gravel/Filter packed: No Size of Gravel Material placed fro ft. to ft.	
Surface seal: Yes To what depth 19 ft. Seal method: Material used in seal BENTONITE Did any strata contain unusable water No Type of water Depth of strata Method of sealing strata off	
PUMP: Manufacture's name Type: H.P. 0	
WATER LEVELS Land-surface elevation above mean sea level: 0 ft. Static level 60 ft. below top of well Date 03/19/2005 Artesian Pressure lbs per square inch Date Artesian water controlled by	
WELL TESTS: Drawdown is amount water level is lowered below static level. Was a pump test made No If yes, by whom Yield gal/min with ft drawdown after Yield gal/min with ft drawdown after Yield gal/min with ft drawdown after Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level) Time: Water Leve Time: Water Leve Time: Water Leve Date of test: Bailer test gal/min ft drawdown after hrs. Air test 2 gal/min w/ stem set at 219 ft. for 1 hours Artesian flow gpm Date Temperature of water Was a chemical analysis made No	

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

Material	From	To
TOPSOIL	0	2
SAND GRAVEL CLAY	2	30
GRAY SAND MEDIUM	30	35
GRAY SAND GRAVEL	35	75
BROWN SAND GRAVEL	75	108
BROWN GRAVEL W/WATER	108	110
LIMESTONE GRAY MED W/FRAC.	110	220

Notes:

APR - 4 2005

DEPARTMENT OF ECOLOGY

Work starte **03/18/2005**

Complete **03/19/2005**

WELL CONSTRUCTION CERTIFICATION:

I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

☒ Driller ☐ Engineer ☐ Trainee

Name: **RONALD HURN** License No.: **2258**

Signature: *Ronald Hurn*

If trainee, Licensed driller is: License No.:

Licensed Driller Signature

Drilling Company:

NAME: **FOGLE PUMP & SUPPLY, INC.**

Shop: **COLVILLE**

ADDRESS: **316 W. 5TH**

Colville, WA 99114

Phone: **509-684-2569** Toll Free: **800-533-6518**

E-Mail: **jrs@foglepump.com**

FAX: **509-684-3032** WEB Site: **www.foglepump.com**

Contractor's

Registration No.: **FOGLEPS095L4**

Date Log Created: **03/24/200**

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.