

WATER WELL REPORT

State of Washington Date Printed: 24-Oct-2012 Log No.
Construction / Decommission: Original 0
Construction Construction Notice

PROPOSED USE: DOMESTIC

TYPE OF WORK: Owners's Well Number: (If more than one well) 1
NEW WELL Method: ROTARY

DIMENSIONS: Diameter of well: 6 inches
Drilled 456 ft. Depth of completed well 456 ft.

CONSTRUCTION DETAILS: Casing installed WELDED
Liner installed: 6" Dia from +2 ft. to 440 ft.
" Dia from ft. to ft. " Dia from ft. to ft.
" Dia from ft. to ft. " Dia from ft. to ft.

Perforations: No Used In:
Type of perforator used
SIZE of perforations in. by in.
Perforations from ft. to ft.
Perforations from ft. to ft.
Perforations from ft. to ft.

Screens: 2 K-Pac Location: 438
Manufacture's Name JOHNSON
Type: STAINLESS Model No
Diam. 5 slot size: BLANK from 452 ft. to 456 ft.
Diam. 5 slot size: .010 from 442 ft. to 452 ft.

Gravel/Filter packed: No Size of Gravel
Material placed from ft. to ft.

Surface seal: Yes To what depth 18 ft.
Seal method: Material used in seal BENTONITE
Did any strata contain unusable water No
Type of water Depth of strata
Method of sealing strata off

PUMP: Manufacture's name
Type: H.P. 0

WATER LEVELS Land-surface elevation above mean sea level: 0 ft.
Static level 55 ft. below top of well Date 09/14/2012
Artesian Pressure lbs per square inch Date
Artesian water controlled by

WELL TESTS: Drawdown is amount water level is lowered below static level.

Was a pump test made No If yes, by whom

Yield: gal/min with ft drawdown after
Yield: gal/min with ft drawdown after
Yield: gal/min with ft drawdown after

Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)

Time:	Water Level	Time:	Water Level	Time:	Water Level

Date of test:
Bailer test gal/min ft drawdown after hrs.
Air test 25 gal/min w/ stem set at 455 ft. for 1 hours
Artesian flow gpm Date
Temperature of water Was a chemical analysis made No

CURRENT

Notice of Intent No.: WE14949

Unique Ecology Well I.D. No BCN983

Water Right Permit Number:

OWNER: BUNNEY, RAY

OWNER ADD 23203 EAST KNOX AVE
LIBERTY LAKE, WA 99019

Well Add HIGHWAY 20

City: Cusick, WA 99119

County: Pend Oreille

Location: SE 1/4 NE 1/4 Sec 09 T 36 R 43 EW

Lat/Long: Lat Deg Lat Min/Sec
(s, t, r still) Long Deg Long Min/Sec
REQUIRED)

Tax Parcel No.: 433609500002

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

Material	From	To
SAND GRAVEL	0	30
SAND BROWN	30	48
CLAY BLUE	48	265
CLAY SILT GRAY BLACK W/WATER	265	435
SAND GRAVEL SILT WATER	435	454
GRANITE SOFT BROWN	454	456

RECEIVED
NOV 28 2012

Notes: DEPARTMENT OF ECOLOGY
EASTERN REGIONAL OFFICE

Work starte 09/10/2012 Complete 09/14/2012

WELL CONSTRUCTION CERTIFICATION:

I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

☒ Driller ☐ Engineer ☐ Trainee

Name: DAVID MEYER License No.: 2427

Signature: 

If trainee, Licensed driller is: License No.:

Licensed Driller Signature

Drilling Company:

NAME: FOGLE PUMP & SUPPLY, INC. Shop: COLVILLE

ADDRESS: 316 W. 5TH

Colville, WA 99114

Phone: 509-684-2569 Toll Free: 800-533-6518

E-Mail: jeanne@foglepump.com

FAX: 509-684-3032 WEB Site: www.foglepump.com

Contractor's
Registration No.: FOGLEPS095L4 Date Log Created: 10/24/2012