



509-680-4605      jclemons@floritellc.com

## FLOW TEST REPORT

Client: Scott Duvall  
Property address: 3089 Hwy 25 N. Northport, Wa  
Test date: 4-16-2025

Water source: Drilled well  
Start Time: 7:51 am  
End Time: 11:51 pm  
Average GPM: 20.3

Water samples taken: Yes, Tri-County  
The water quality report will be emailed to you as soon as it is received back from the lab.

Notes:  
4-hour flow test  
Well tag ID BNP 272  
1 1/2 control box  
40/60 pressure switch  
The test was conducted from the frost-free spigot next to the wellhead.  
All other components functioned properly at the time of the test.

Client paid at the time of service. Thank you.

Thank you for your business. If you have any questions, please don't hesitate to call or email.

Jeff Clemons

\*Please see definitions, additional terms and disclaimers on the following page.

## WELL REPORT DEFINITIONS, ADDITIONAL TERMS AND DISCLAIMERS

**Sole report.** This report contains the sole observations and conclusions of Flo-Rite Well Water Testing LLC (hereinafter the company) pertaining to the testing of the Customer's well. Any prior statements of the agents or employees of the company which are not contained herein are superseded by this report and shall be relied upon at the Customer's own voluntary risk.

**Test limitations.** The data and conclusions provided are based upon the tests and measurements of the company using standard and accepted practices of the groundwater industry. However, conditions in water wells are subject to dramatic changes in even short periods of time. Additionally, the techniques employed may be subject to considerable error due to factors within the well and groundwater formation which are beyond the company's immediate control or observation. Therefore, the data are valid only as of the date and to the extent of the observational limitations of the test.

**Use of test.** The test conclusions are intended for general comparison of the well in its present condition against known water well standards or guidelines and should not be relied upon to predict either the future quantity or quality of water that the well will produce. Wells should be periodically re-tested to show both seasonal and long-term fluctuations.

**Definitions.** GPM = gallons per minute. HP=horsepower

**Disclaimers.** In presenting the data and conclusions, the company makes no warranties, either express or implied, as to future water production of the well. Further, the company, unless expressly stated to the contrary, does not represent (1) that the well or pump system is in any particular condition or state of repair, or (2) that the test results will satisfy cognizant governmental ordinances or regulations, or (3) that the test duration or methodology is sufficient to meet local water system or new construction permit standards (which may require 24 hour or more tests), or (4) that the water is adequate for a particular purpose contemplated by Customer, or (5) the usefulness of the report for any purpose more than one year after the date of the test.

**Customer's release.** In accepting this report, the Customer releases and holds the company harmless from liability for consequential or incidental damages arising (1) out of the breach of an express or implied warranty of future water production, or (2) in any manner through the further dissemination of this report, or its conclusions, by either customer or third parties, except as the dissemination is required to complete the project or other activity for which the report was prepared.