

WATER WELL REPORT

State of Washington Date Printed: 19-Oct-2007 Log No.

Construction / Decommission: Original

Construction Construction Notice

0
274696**CURRENT**

Notice of Intent No.: W252918

Unique Ecology Well I.D. No ALN810

Water Right Permit Number:

OWNER: THOMPSON, MIKE & TONI

OWNER ADD PO BOX 302

CURLEW, WA 99118

Well Add 1239 KEWA-METEOR RD

City: Inchelium, WA 99138

County: Ferry

Location: SW 1/4 SE 1/4 Sec 9 T 32 R 36E EW

Lat/Long: Lat Deg Lat Min/Sec

(s, t, r still) Long Deg Long Min/Sec

REQUIRED) Long Min/Sec

Tax Parcel No.: 63209420001002

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

Material	From	To
TOP SOIL	0	2
CLAY GRAVEL COBBLES	2	21
GRAY CLAY GRAVEL BORKEN ROCK	21	42
BROKEN ROCK W/WATER	42	50
SHALE BLACK SOFT	50	100

RECEIVED

OCT 29 2007

DEPARTMENT OF ECOLOGY
EASTERN REGIONAL OFFICE**Notes:**

CASING STAR PERFORATED FROM 42-50', 4 ROWS W/ 120 PERFS

Work starte 08/24/2007

Complete 08/27/2007

WELL CONSTRUCTION CERTIFICATION:

I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

☒ Driller ☐ Engineer ☐ Trainee

Name: DAVID MEYER

License No.: 2427

Signature: _____

If trainee, Licensed driller is: _____

License No.: _____

Licensed Driller Signature _____

Drilling Company:

NAME: FOGLE PUMP & SUPPLY, INC.

Shop: COLVILLE

ADDRESS: 316 W. 5TH

Colville, WA 99114

Phone: 509-684-2569

Toll Free: 800-533-6518

E-Mail: jeanne@foglepump.com

FAX: 509-684-3032

WEB Site: www.foglepump.com

Contractor's

Registration No.: FOGLEPS095L4

Date Log Created: 09/05/2007

PROPOSED USE: DOMESTIC

TYPE OF WORK: Owners's Well Number: (If more than one well)

NEW WELL

Method: ROTARY

DIMENSIONS Diameter of well: 6 inches
Drilled 100 ft. Depth of completed well 100 ft.**CONSTRUCTION DETAILS:**

Casing installed WELDED

Liner installed: PVC

4 " Dia from 40 ft. to 100 ft.

6 " Dia from +2 ft. to 55 ft.

" Dia from ft. to ft.

" Dia from ft. to ft.

Perforations: Yes Used In: LINER & CA

Type of perforator used SKILL SAW

SIZE of perforations 1/4 in. b 6 in.

40 Perforation from 60 ft. to 100 ft.

Perforation from ft. to ft.

Perforation from ft. to ft.

Screens: No K-Pac Location

Manufacture's Name

Type: Model No

Diam. slot size from ft. to ft.

Diam. slot size from ft. to ft.

Gravel/Filter packed: No Size of Gravel

Material placed fro ft. to ft.

Surface seal: Yes To what depth 18 ft.

Seal method: Material used in seal BENTONITE

Did any strata contain unusable water No

Type of water Depth of strata

Method of sealing strata off

PUMP: Manufacture's name

Type: H.P. 0

WATER LEVELS Land-surface elevation above mean sea level: 0 ft.

Static level 20 ft. below top of well Date 08/27/2007

Artesian Pressure lbs per square inch Date

Artesian water controlled by

WELL TESTS: Drawdown is amount water level is lowered below static level.

Was a pump test made No If yes, by whom

Yield gal/min with ft drawdown after

Yield gal/min with ft drawdown after

Yield gal/min with ft drawdown after

Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level)

Time: Water Level Time: Water Level Time: Water Level

Date of test:

Bailer test gal/min ft drawdown after hrs.

Air test 5 gal/min w/ stem set at 99 ft. for 1 hours

Artesian flow gpm Date

Temperature of water Was a chemical analysis made No