

WATER WELL REPORT

Start Card No. W110919

Unique Well I.D. # AEL836

Water Right Permit No.

STATE OF WASHINGTON

(1) OWNER: Name BASARGIN, STEFAN Address PO BOX 3363 HOMER, AK 99603-

(2) LOCATION OF WELL: County STEVENS

- SW 1/4 NE 1/4 Sec 13 T 27 N., R 39E WM

(2a) STREET ADDRESS OF WELL (or nearest address),

(3) PROPOSED USE: DOMESTIC

(10) WELL LOG

(4) TYPE OF WORK: Owner's Number of well
(If more than one) 2
NEW WELL Method: ROTARY

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

(5) DIMENSIONS: Diameter of well 6 inches
Drilled 340 ft. Depth of completed well 340 ft.

MATERIAL	FROM	TO
SAND GRAVEL WITH COBBLES	0	54
SAND COARSE	54	62
CLAY GRAY	62	77
COARSE SAND	77	187
FINE SILTY SAND WITH SOME BROWN CLAY	187	232
CLAY GRAY	232	270
SANDY GRAY CLAY	270	285
FINE SAND W/WATER	285	329
FINE SAND SOME GRAVEL W/WATER	329	340

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Dia. from +2 ft. to 335 ft.
WELDED 5 " Dia. from 330 ft. to 335 ft.
" Dia. from ft. to ft.

Perforations: NO

Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: YES

Manufacturer's Name JOHNSON
Type SLOTTED Model No. STAINLESS
Diam. S slot size 15 from 335 ft. to 340 ft.
Diam. slot size from ft. to ft.

Gravel packed: NO

Size of gravel
Gravel placed from ft. to ft.

Surface seal: YES

To what depth? 20 ft.

Material used in seal BENTONITE

Did any strata contain unusable water? NO

Type of water? Depth of strata ft.

Method of sealing strata off

(7) PUMP: Manufacturer's Name

Type NONE H.P.

(8) WATER LEVELS: Land-surface elevation
above mean sea level ... ft.

Static level 220 ft. below top of well Date

Artesian Pressure lbs. per square inch Date

Artesian water controlled by

Work started 09/21/99

Completed 09/23/99

(9) WELL TESTS: Drawdown is amount water level is lowered below static level.

Was a pump test made? NO If yes, by whom?

Yield: gal./min with ft. drawdown after hrs.

Recovery data

Time Water Level Time Water Level Time Water Level

Date of test / /

Bailer test gal/min. ft. drawdown after hrs.

Air test 15 gal/min. w/ stem set at 340 ft. for 2 hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? NO

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME FOGLE PUMP & SUPPLY, INC.

(Person, firm, or corporation) (Type or print)

ADDRESS POB 1450, RIVER MTS. WA.

[SIGNED] License No. 2321

Contractor's

Registration No. FOGLEPS09514

Date 10/05/99