

WATER WELL REPORT

State of Washington Date Printed: **24-Mar-2008** Log No. **0**
 Construction / Decommission: Original Construction Notice
 Construction

PROPOSED USE: DOMESTIC	
TYPE OF WORK: Owners's Well Number: (If more than one well) NEW WELL Method: ROTARY	
DIMENSIONS Diameter of well: 6 inches Drilled 230 ft. Depth of completed well 228 ft.	
CONSTRUCTION DETAILS:	Casing installed WELDED
Liner installed: PVC 4 " Dia from 10 ft. to 230 ft.	6 " Dia from +2 ft. to 18 ft. " Dia from ft. to ft. " Dia from ft. to ft.
Perforations: Yes Used In: LINER Type of perforator used SKILL SAW SIZE of perforations 1/8 in. b 7 in. 60 Perforation from 170 ft. to 230 ft. Perforation from ft. to ft. Perforation from ft. to ft.	
Screens: No K-Pac Location Manufacture's Name Type: Model No Diam. slot size from ft. to ft. Diam. slot size from ft. to ft.	
Gravel/Filter packed: No Size of Gravel Material placed from ft. to ft.	
Surface seal: Yes To what depth 18 ft. Seal method: Material used in seal BENTONITE Did any strata contain unusable water No Type of water Depth of strata Method of sealing strata off	
PUMP: Manufacture's name Type: H.P. 0	
WATER LEVELS Land-surface elevation above mean sea level: 0 ft. Static level 8 ft. below top of well Date 11/30/2007 Artesian Pressure lbs per square inch Date Artesian water controlled by	
WELL TESTS: Drawdown is amount water level is lowered below static level. Was a pump test made No If yes, by whom Yield gal/min with ft drawdown after Yield gal/min with ft drawdown after Yield gal/min with ft drawdown after Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level) Time: Water Level Time: Water Level Time: Water Level Date of test: Bailer test gal/min ft drawdown after hrs. Air test 50+ gal/min w/ stem set at 229 ft. for 1 hours Artesian flow gpm Date Temperature of water Was a chemical analysis made No	

CURRENT

Notice of Intent No.: **WEO7779**Unique Ecology Well I.D. No **BAB655**

Water Right Permit Number:

OWNER: **McCain, PAM**OWNER ADD **P O BOX 6073 PINE MOUNTAIN****FRAZIER PARK, CA 93222**Well Add **1622-C CLUGSTON ONION CRK**City: **Colville, WA 99114**County: **Stevens**Location: **NE 1/4 NW 1/4 Sec 36 T 38 R 39E EW**

Lat/Long: Lat Deg Lat Min/Sec

(s, t, r still

REQUIRED)

Long Deg

Long Min/Se

Tax Parcel No.: **2370200**

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

Material	From	To
TOP SOIL	0	3
GREY CLAY GRAVEL	3	14
S&P GRANITE HARD	14	172
BROWN GRANITE SOFT	172	223
S&P GRANITE FRAC W/WATER	223	228

RECORDED
 APR 30 2008

Notes:

DEPARTMENT OF ECOLOGY
 EASTERN REGIONAL OFFICE

Work starte **11/30/2007**Complete **11/30/2007**

WELL CONSTRUCTION CERTIFICATION:

I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

☐ Driller ☐ Engineer ☒ Trainee

Name: **ANDY BAKER**License No.: **2892T**Signature: *Andy Baker*If trainee, Licensed driller is: **RONALD HURN**License No.: **2258**Licensed Driller Signature: *Ronald Hurn*

Drilling Company:

NAME: **FOGLE PUMP & SUPPLY, INC.**Shop: **COLVILLE**ADDRESS: **316 W. 5TH****Colville, WA 99114**Phone: **509-684-2569**Toll Free: **800-533-6518**E-Mail: **jeanne@foglepump.com**FAX: **509-684-3032**WEB Site: **www.foglepump.com**

Contractor's

Registration No.: **FOGLEPS095L4**Date Log Created: **12/10/200**