IF TRAINEE: Sponsor's License No.

Sponsor's Signature

WATER WELL BERORT DEPARTMENT OF	N. C. C. L. WEADOOC	The same of the sa	E Nome
WATER WELL REPORT ECOLOGY	Notice of Intent No. WE42926	CEN	/ED
Type of Work: State of Washington	Unique Ecology Well ID Tag No. BMH845		
Construction	Site Well Name (if more than one well):	IN 2 2 2	กวา
☐ Decommission	Water Right Permit/Certificate No.	to the U	021
Proposed Use:  Domestic  Industrial  Municipal	Property Owner Name JOSEPH COBURNIC PARTY AND STREET Address 3159 HEATHER AND	tmant of	Foot
☐ Dewatering ☐ Irrigation ☐ Test Well ☐ Other	Well Street Address 3159 HEATHER LANE	MINGHE OF	Ecology
Construction Type: Method:	Well Street Address 3159 HEATHER AND County STEVEN	yyasning vs	ton Office
■ New well     □ Alteration     □ Driven     □ Jetted     □ Cable Tool       □ Deepening     □ Other     □ Dug     ■ Air-     □ Mud-Rotary	Tax Parcel No. 0422200		
Dimensions: Diameter of boring 6 in., to 143 ft.			
Depth of completed well 140 ft.	Was a variance approved for this well? ☐ Yes ■ No		
Construction Details: Wall	If yes, what was the variance for?		
Casing Liner Diameter From To Thickness Steel PVC Welded Thread			
■   □ <u>6 in. +3 120in.</u> ■   □ ■   □	Location (see instructions on page 2):  SE ¼-¼ of the SE ¼; Section 14 Township 39 Range 40		
inin.	Latitude (Example: 47.12345)		
	Longitude (Example: -120.12345)		
Perforations:     □ Yes     ■ No     Type of perforator used       No. of perforations	Driller's Log/Construction or Decommission Procedure		
No. of perforations in. by in.  Perforated from ft. to ft. below ground surface	Formation: Describe by color, character, size of material and nature of the material in each layer penetrated, with at least of		
Screens: ■ Yes □ No ■ K-Packer ➡ Depth 127 ft.	information. Use additional sheets if necessary.	one entry for eac	in change of
Manufacturer's Name ALLOY MACHINE	Material	From	То
Type STAINLESS Model No.	SAND GRAVELS NO WATER	0	18
Diameter5 in. Slot size18 in. from128 ft. to140 ft. Diameter in. Slot size in. from ft. to ft.	COARSE SAND	18	30
	GRAY CLAY	30	115
Sand/Filter pack: ☐ Yes ■ No Size of pack material in.	GRAVELS SAND	115	120
Materials placed from ft. to ft.	GRAY CLAY	120	125
Surface Seal:  Yes  No To what depth?  18 ft.  Material used in seal BENTONITE	SAND GRAVELS	125	140
Did any strata contain unusable water?   Yes  No	GRAY CLAY	140	143
Type of water? Depth of strata			
Method of sealing strata off		-	
Pump: Manufacturer's Name Type:		-	
H.P Pump intake depth: ft. Designed flow rate: gpm			
Water Levels: Land-surface elevation above mean sea level 1847 ft.			
Stick-up of top of well casing ft. above ground surface			
Static water level 41 ft. below top of well casing Date 05/25/2021  Artesian pressure lbs. per square inch Date			
Artesian water is controlled by (cap, valve, etc.)			
Assertion of the second of the			
Well Tests:  Was a pumping test performed? □ No □ Yes ⇒ by whom?			
Yield gpm with ft. drawdown after hrs.	RECEIVED		
Yield gpm with ft. drawdown after hrs.	DEPARTMENT OF ECOLOGY		
Yield gpm with ft. drawdown after hrs.  Recovery data (time = zero when pump is turned off – water level measured from well	HIM AD Q 2024		
top to water level)	JUN 28 2021		
Time Water Level Time Water Level Time Water Level	WATER RESOURCES PROGRAM	,	
	EASTERN REGIONAL OFFICE		
Date of pumping test			
Bailer testgpm withft. drawdown afterhrs.  Air test10gpm with stem set at128ft. for1hrs Date05/25/2021			
Arr test 10 gpm with stem set at 120 ft. for 1 hrs. Date 03/23/2021  Artesian flow gpm			
Temperature of water ° F Was a chemical analysis made? ☐ Yes ■ No	Start Date 05/24/2021 Completed Date	05/25/2021	
WELL CONSTRUCTION CERTIFICATION: I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well			
well constructed and/or accept re- construction standards. Materials used and the information reported above are true		nce with all W	asinigun wen
and the internation reported work and the			
■ Driller □ Trainee □ PE – Print Name AUSTIN GEE	Drilling Company FOGLE PUMP & SUPPLY,	INC.	
Signature Curl	Address 2250 NORTH HIGHWAY		
License No. 3335	City, State, Zip COLVILLE, WA 99114		

Contractor's

Registration No. FOGLEPS095L4

Date 05/25/2021