

File Original and First Copy with
Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No.

W 061086

UNIQUE WELL I.D. # ABM 843

Water Right Permit No.

OWNER: Name Steve Phelps Address W3921 Owens Deer Park, WA 99006

(2) LOCATION OF WELL: County Spokane NE 1/4 NW 1/4 Sec 23 T. 28 N. R. 42 W.M.

(2a) STREET ADDRESS OF WELL (or nearest address)

(3) PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal ☐
☐ Irrigation ☐ Test Well ☐ Other ☐
☐ DeWater

(4) TYPE OF WORK: Owner's number of well (if more than one)
Abandoned ☐ New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☐ Driven ☐
Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 209 feet. Depth of completed well 209 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 Diam. from +2 ft. to 18 ft.
Welded ☐ 4 Diam. from 7 ft. to 209 ft.
Liner installed ☐
Threaded ☐ Diam. from _____ ft. to _____ ft.

Perforations: Yes ☐ No ☐

Type of perforator used skill saw

SIZE of perforations 1/8 in. by 5 in.
189 perforations from 20 ft. to 209 ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

Screens: Yes ☐ No ☐

Manufacturer's Name _____

Type _____ Model No. _____

Diam. _____ Slot size _____ from _____ ft. to _____ ft.

Diam. _____ Slot size _____ from _____ ft. to _____ ft.

Gravel packed: Yes ☐ No ☐ Size of gravel _____

Gravel placed from _____ ft. to _____ ft.

Surface seal: Yes ☐ No ☐ To what depth? 18 ft.

Material used in seal Bentonite

Did any strata contain unusable water? Yes ☐ No ☐

Type of water? _____ Depth of strata _____

Method of sealing strata off _____

(7) PUMP: Manufacturer's Name _____
Type: _____ H.P. _____

(8) WATER LEVELS: Land-surface elevation above mean sea level _____ ft.
Static level 20 ft. below top of well Date _____
Artesian pressure _____ lbs. per square inch Date _____
Artesian water is controlled by _____ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes ☐ No ☐ If yes, by whom? _____

Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.

" " " "

" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time Water Level Time Water Level Time Water Level

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information

MATERIAL	FROM	TO
Top soil	0	2
Sand	2	7
Basalt broken soft	7	16
Basalt med	16	47
Basalt hard	47	65
Basalt med	65	87
Basalt broken soft	87	102
Basalt broken med	102	208
Clay brn	208	209

Work Started 6-27, 19 95 Completed 6-29, 19 95

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME MINDEN DRILLING INC.
(PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address N 31621 Cedar Deer Park, WA 99006

(Signed) Darin Minden License No. 2208
(WELL DRILLER)

Contractor's
Registration
No. MINDEDI090J9 Date 7-11, 1995

(USE ADDITIONAL SHEETS IF NECESSARY)

Ecology is an Equal Opportunity and Affirmative Action employer. For special accommodation needs, contact the Water Resources Program at (206) 407-6600. The TDD number is (206) 407-6008.