

File Original and First Copy with
Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. 21989

UNIQUE WELL I.D. # aaj 999

Water Right Permit No.

OWNER: Name Donald W. Stindle

Address 13011 Seattle Hill RD. Snohomish WA 982

(2) LOCATION OF WELL: Stevens

SE 1/4 SW 1/4 Sec 3 T. 37 N. R. 38E W.M.

(2a) STREET ADDRESS OF WELL (or nearest address)

(3) PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal ☐
☐ Irrigation ☐ Test Well ☐ Other ☐
☐ On Water ☐

(4) TYPE OF WORK: 3rd

Abandoned ☐ New well ☒ Method: ☐ Dug ☐ Bored ☐
☐ Drilled ☐ Cased ☐ Driven ☐
☐ Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches
Drilled 154 feet Depth of completed well 154 feet

(6) CONSTRUCTION DETAILS:

Casing installed ☒ from ft. to 154 ft.
Welded ☒ from ft. to 154 ft.
Liner installed ☒ from ft. to 154 ft.
Threaded ☐ from ft. to 154 ft.

Perforations: Yes ☐ No ☒

Type of perforator used

SIZE of perforations 1/2 by 1/2 in.

perforations from ft. to ft.

perforations from ft. to ft.

perforations from ft. to ft.

Screen: Yes ☒ No ☐

Manufacturer's Name Krypton

Type stainless steel telescoping Model No.

Diam. 5" Slot size 0.018 ft. to 149 ft. to 154 ft.

Diam. 5" Slot size 0.018 ft. to 149 ft. to 154 ft.

Gravel packed: Yes ☐ No ☒ Size of gravel

Gravel placed from ft. to ft.

Surface used: Water to water depth? 13 ft.

Material used in seal Sealant

Did any fluids contain oil or grease? Yes ☐ No ☒

Type of water? Groundwater Depth of water

Method of sealing around well

(7) PUMP: Manufacturer's Name

Type H.P.

(8) WATER LEVELS: Static 116 ft. 5-17-94

Artesian pressure ft. to ft. Date 5-17-94

Artesian water is produced by (See notes, etc.)

(9) WELL TESTS: Discharge 1.3 1.43 1

Was a pump test made? Yes ☐ No ☒ If yes, by whom?

Yield 1.3 1.43 1 ft. to ft.

Recovery data (time taken to drop when pump is turned off) ft. to ft.

Time Water Level ft. to ft. Water Level ft. to ft.

Time Water Level ft. to ft. Water Level ft. to ft.

Time Water Level ft. to ft. Water Level ft. to ft.

Time Water Level ft. to ft. Water Level ft. to ft.

Time Water Level ft. to ft. Water Level ft. to ft.

Time Water Level ft. to ft. Water Level ft. to ft.

Time Water Level ft. to ft. Water Level ft. to ft.

Time Water Level ft. to ft. Water Level ft. to ft.

Time Water Level ft. to ft. Water Level ft. to ft.

Time Water Level ft. to ft. Water Level ft. to ft.

Time Water Level ft. to ft. Water Level ft. to ft.

Time Water Level ft. to ft. Water Level ft. to ft.

Time Water Level ft. to ft. Water Level ft. to ft.

Time Water Level ft. to ft. Water Level ft. to ft.


(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
overburden (dirt)	0	4
clay (brown)	4	13
sands (med)		
some gravel 10%	13	116
sands water bearing	116	154
10 - 15 GPM		

5"x5"x.018 slot
stainless steel screen
installed from 149' to 154'

well is making 13 GPM
with air test



Work started 5-16 1994 Completed 5-17-94 1994

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME Fogle Pump (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address 316 W 5th Colville WA 99114

(Signed) Terry Carkill/DB License No. 1895

Contractor's Registration No. Fogle ps09514 Date 5-17-94 1994

(USE ADDITIONAL SHEETS IF NECESSARY)