

WATER WELL REPORT

Start Card No. 55215

Inv > 923384

STATE OF WASHINGTON

Water Right Permit No.

1) OWNER: Name Robert Charbonneau		Address P.O.B. 749 Republic, WA																						
2) LOCATION OF WELL: County Ferry		NW SE 18 T 37 N, R. 33 W.M.																						
3) STREET ADDRESS OF WELL (or nearest address) Barrett Creek Road Republic, WA																								
4) PROPOSED USE: ☒ Domestic ☐ Irrigation ☐ DeWater ☐ Industrial ☐ Test Well ☐ Municipal ☐ Other		(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION																						
5) TYPE OF WORK: Owner's number of well (if more than one) Abandoned ☐ New well ☒ Deepened ☐ Reconditioned ☐ Method: Dug ☐ Bored ☐ Cable ☐ Driven ☐ Rotary ☒ Jetted ☐		Formation. Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated with at least one entry for each change of information. <table border="1" style="width:100%; border-collapse: collapse;"><thead><tr><th>MATERIAL</th><th>FROM</th><th>TO</th></tr></thead><tbody><tr><td>Clay, silt; gravel</td><td>0</td><td>26</td></tr><tr><td>Basalt-gray, soft</td><td>26</td><td>42</td></tr><tr><td>Basalt-gray, medium</td><td>42</td><td>230</td></tr><tr><td>Basalt-gray, fractured</td><td>230</td><td>235</td></tr><tr><td>Basalt-gray, medium</td><td>235</td><td>369</td></tr><tr><td>Basalt-gray, fractured</td><td>369</td><td>370</td></tr></tbody></table>		MATERIAL	FROM	TO	Clay, silt; gravel	0	26	Basalt-gray, soft	26	42	Basalt-gray, medium	42	230	Basalt-gray, fractured	230	235	Basalt-gray, medium	235	369	Basalt-gray, fractured	369	370
MATERIAL	FROM	TO																						
Clay, silt; gravel	0	26																						
Basalt-gray, soft	26	42																						
Basalt-gray, medium	42	230																						
Basalt-gray, fractured	230	235																						
Basalt-gray, medium	235	369																						
Basalt-gray, fractured	369	370																						
6) DIMENSIONS: Diameter of well 6 inches. Drilled 370 feet. Depth of completed well 370 ft.																								
7) CONSTRUCTION DETAILS: Casing installed: 6" Diam. from +1 ft. to 26 ft. Welded ☒ Liner installed ☒ Threaded ☐ Type of perforator used _____ SIZE of perforations _____ in. by _____ in. Screens: Yes ☐ No ☒ Manufacturer's Name _____ Type _____ Model No. _____ Gravel packed: Yes ☐ No ☒ Size of gravel _____ Surface seal: Yes ☒ No ☐ To what depth? 18 ft. Material used in seal Bentonite Did any strata contain unusable water? Yes ☐ No ☒ Type of water? _____ Depth of strata _____ Method of sealing strata off _____																								
8) PUMP: Manufacturer's Name _____ Type: _____ H.P. _____																								
9) WATER LEVELS: Land surface elevation above mean sea level _____ ft. Static level 30 ft. below top of well Date 7/27/92 Artesian pressure _____ lbs. per square inch Date _____ Artesian water is controlled by _____ (Cap, valve, etc.)																								
10) WELL TESTS: Drawdown is amount water level is lowered below static level Was a pump test made? Yes ☐ No ☒ If yes, by whom? _____ Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs. Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level) <table border="1" style="width:100%; border-collapse: collapse;"><thead><tr><th>Time</th><th>Water Level</th><th>Time</th><th>Water Level</th><th>Time</th><th>Water Level</th></tr></thead><tbody><tr><td></td><td></td><td></td><td></td><td></td><td></td></tr></tbody></table> Date of test _____ Galer test 50 gal./min. with 370 ft. drawdown after 0.5 hrs. Art test _____ gal./min. with stem set at _____ ft. for _____ hrs. Artesian flow _____ g.p.m. Date _____ Temperature of water _____ Was a chemical analysis made? Yes ☐ No ☒		Time	Water Level	Time	Water Level	Time	Water Level																	
Time	Water Level	Time	Water Level	Time	Water Level																			
		Work started 7/23/92 , 19. Completed 7/24/92 , 19.																						
		WELL CONSTRUCTOR CERTIFICATION: I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief. NAME Eagle Pump & Drilling West (PERSON, FIRM OR CORPORATION) (TYPE OR PRINT) P.O. Box 147, Malo WA 99150 Address _____ (Signed) William B. Davis License No. 1356 (WELL DRILLER) Contractor's Registration #PS 095 L4 Date 7/24/92 No. _____																						

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

