The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Application No. .....

Permit No. .....

(1) OWNER: Name Jerry Klasens Address 1312 E 38th Spokane Wash.

LOCATION OF WELL: County Stevens NW ¼ NW ¼ Sec 24 T 30 N., R 46 W.M.

Bearing and distance from section or subdivision corner

(3) PROPOSED USE: Domestic ☒ Industrial ☐ Municipal ☐ Irrigation ☐ Test Well ☐ Other ☐

(4) TYPE OF WORK: Owner's number of well (if more than one) .....
New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☐ Driven ☐
Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 770 ft. Depth of completed well 770 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from +1 ft. to 196" ft.
Threaded ☐ " Diam. from ft. to ft.
Welded ☐ " Diam. from ft. to ft.

Perforations: Yes ☒ No ☐ P.V.C. 4"
Type of perforator used SAW
SIZE of perforations 1/8 in. by 4 in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☐ No ☒
Manufacturer's Name
Type Model No.
Diam. Slot size from ft. to ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☐ Size of gravel:
Gravel placed from ft. to ft.

Surface seal: Yes ☒ No ☐ To what depth? ft.
Material used in seal Bentonite
Did any strata contain unusable water? Yes ☐ No ☒
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type: H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level 2200 ft.
Static level ft. below top of well Date
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☒ No ☐ If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test 6/30/77
Bailer test 1+ gal./min. with ft. drawdown after hrs.
Artesian flow g.p.m. Date
Temperature of water Cold Was a chemical analysis made? Yes ☐ No ☒

(10) WELL LOG:

Formation: *Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.*

MATERIAL	FROM	TO
Basalt Rock - Boulders	0	32
Basalt + Clay	32	37
Fractured Basalt	37	46
Basalt + Clay	46	73
Decomposed Granite Red Quartz Seams	73	87
Decomposed Granite Gray Mica	87	127
Quartz Seams.	127	130
Decomposed Granite Gray Mica	130	168
Gray Granite	168	320
Firm Gray Granite.	320	400
Firm Gray + Black Granite	400	427
Quartz Seams + Gray Granite	427	543
Black Granite + Quartz	543	644
Gray Granite	644	685
Some Quartz	685	720
Soft Seams / Damp.	720	770

Work started 6/23/77 19 Completed 6/30 19 77

WELL DRILLER'S STATEMENT:

This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME American Drilling (Person, firm, or corporation) (Type or print)

Address P.O. Box 14977 Spokane, Wash 99214

[Signed] B.O. Mungall (Well Driller)

License No. 0322 Date 7/30 19 77

Springdale 7½
Deer Lake

12/6/78

(USE ADDITIONAL SHEETS IF NECESSARY)

ECY 050-1-20