Well report

WATER WELL REPORT

Start Card No. W599110
Well ID No. ABT-950
Water Right Permit No. 99114

(1) OWNER: Name Roger Coleman Address 346 Old Dominion Rd. Colville, WA.

(2) LOCATION OF WELL: County Stevens NW ¼ SW ¼ Sec. 7 T. 35 N. R. 39E W.M.

(2a) STREET ADDRESS OF WELL (or nearest address)

(3) PROPOSED USE: [X] Domestic [ ] Irrigation [ ] DeWater Industrial [ ] Test Well [ ] Municipal [ ] Other [ ]

(4) TYPE OF WORK: Owner's number of well (if more than one)
Abandoned [ ] New well [ ] Deepened [X] Reconditioned [ ] Method: Dug [ ] Cable [ ] Rotary [X] Bored [ ] Driven [ ] Jetted [ ]

(5) DIMENSIONS: Diameter of well 6 inches
Drilled 139'-200' feet Depth of completed well 200 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6" Diam from 139 ft to 147 ft
Welded
Liner installed 4" x 200 psi PVC Diam from 120 ft to 200 ft
Threaded [ ] Diam from ft to ft

Perforations: Yes [X] No [ ]
Type of perforator used Star (Air Perforator)
SIZE of perforations 1" in by 1/2 in.
5 slots/Every 2" perforations from 132 ft. to 140 ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes [ ] No [X]
Manufacturer's Name
Type Model No.
Diam Slot size from ft. to ft.
Diam Slot size from ft. to ft.

Gravel packed: Yes [ ] No [X] Size of gravel
Gravel placed from ft. to ft.

Surface seal: Yes [ ] No [ ] To what depth? ft.
Material used in seal Existing
Did any strata contain unusable water? Yes [ ] No [X]
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type: H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ft.
Static level 130 ft. below top of well Date 8/10/95
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes [ ] No [X] If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test

Bailer test gal./min. with ft. drawdown after hrs.
Airtest 2 gal./min. with stem set at 198 ft. for 1 hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes [ ] No [ ]

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
Cemented Small Gravels (wet)	139	147
Black Shale w/ White Quartz Stringers	147	200

4" x 200 psi PVC Liner installed from 120'-200' perforated from 160'-200'

#160575

THIS ORIGINAL WELL REPORT MUST BE COMPLETELY FILLED OUT AND SIGNED BY DRILLER, THIS IS THE OFFICIAL COPY.

Work started 8/9/95, 19. Completed 8/10/95, 19.

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME Fogle Pump & Supply Inc. (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)
Address 316 W. 5th / Colville, WA. 99114
(Signed) Jerry D. Corkill (WELL DRILLER) License No. 1895
Contractor's Registration No. Date, 19.

(USE ADDITIONAL SHEETS IF NECESSARY)