File Original and First Copy with Department of Ecology
Second Copy—Owner's Copy
Third Copy—Driller's Copy

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. 58456

Water Right Permit No. 99141

(1) OWNER: Name Randy Hankey Address 2709 House Rd., Kettle FAlls, WA

(2) LOCATION OF WELL: County Stevens NW ¼ SW ¼ Sec 10 T. 38 N., R 37 W.M.

(2a) STREET ADDDRESS OF WELL (or nearest address)

(3) PROPOSED USE: [X] Domestic [ ] Irrigation [ ] DeWater Industrial [ ] Test Well [ ] Municipal [ ] Other [ ]

(4) TYPE OF WORK: Owner's number of well (if more than one)

Abandoned [ ] New well [X] Deepened [ ] Reconditioned [ ]

Method: Dug [ ] Cable [ ] Rotary [X] Bored [ ] Driven [ ] Jetted [ ]

(5) DIMENSIONS: Diameter of well 6 inches.

Drilled 340 feet. Depth of completed well 340 ft.

(6) CONSTRUCTION DETAILS:

Casing installed: 6 " Diam. from +1 ft. to 34 ft.

Welded [X] 4 " Diam. from 20 ft. to 340 ft.

Liner installed [X]

Threaded [ ] " Diam. from ft. to ft.

Perforations: Yes [X] No [ ]

Type of perforator used saw

SIZE of perforations ¼ in. by 6 in.

40 perforations from 260 ft. to 340 ft.

perforations from ft. to ft.

perforations from ft. to ft.

Screens: Yes [ ] No [X]

Manufacturer's Name

Type Model No.

Diam. Slot size from ft. to ft.

Diam. Slot size from ft. to ft.

Gravel packed: Yes [ ] No [X] Size of gravel

Gravel placed from ft. to ft.

Surface seal: Yes [X] No [ ] To what depth? 18 ft.

Material used in seal Bentonite

Did any strata contain unusable water? Yes [ ] No [X]

Type of water? Depth of strata

Method of sealing strata off

(7) PUMP: Manufacturer's Name

Type: H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ft.

Static level ft. below top of well Date

Artesian pressure lbs. per square inch Date

Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level

Was a pump test made? Yes [ ] No [X] If yes, by whom?

Yield: gal./min. with ft. drawdown after hrs.

" " " "

" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test

Bailer test gal./min. with ft. drawdown after hrs.

Airtest 2½ gal./min. with stem set at ft. for hrs.

Artesian flow g.p.m. Date

Temperature of water Was a chemical analysis made? Yes [ ] No [X]

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
Sand & gravel, clay	0	35
Soft grey slate	35	160
Med. soft slate, green	160	340
water 260'		
#124337		

Work started 10/12, 19. Completed 10/13, 1992

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME FOGLE PUMP & SUPPLY, INC. (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address 316 W. 5th Colville, WA. 99114

(Signed) Mike Ball /gm (WELL DRILLER) License No. 1251

Contractor's Registration No. FOGLEPS095L4 Date 10-13, 1992

(USE ADDITIONAL SHEETS IF NECESSARY)

CY 050-1-20 (10/87) -1329- 18