

WATER WELL REPORT

State of Washington Date Printed: 20-Nov-2007 Log No.
 Construction / Decommission: Original
 Construction Construction Notice 283531

PROPOSED USE: DOMESTIC	
TYPE OF WORK: Owners's Well Number: (If more than one well) 1 NEW WELL Method: ROTARY	
DIMENSIONS Diameter of well: 6 inches Drilled 180 ft. Depth of completed well 180 ft.	
CONSTRUCTION DETAILS:	Casing installed WELDED
Liner installed: PVC 4 " Dia from 40 ft. to 180 ft.	6 " Dia from +2 ft. to 122 ft. " Dia from ft. to ft. " Dia from ft. to ft.
Perforations: Yes Used In: LINER Type of perforator used SKILL SAW Size of perforations 1/8 in. b 6 in. 120 Perforation from 100 ft. to 180 ft. Perforation from ft. to ft. Perforation from ft. to ft.	
Screens: No K-Pac Location Manufacture's Name Type: Model No Diam. slot size from ft. to ft. Diam. slot size from ft. to ft.	
Gravel/Filter packed: No Size of Gravel Material placed fro ft. to ft.	
Surface seal: Yes To what depth 18 ft. Seal method: Material used in seal BENTONITE Did any strata contain unusable water No Type of water Depth of strata Method of sealing strata off	
PUMP: Manufacture's name Type: H.P. 0	
WATER LEVELS Land-surface elevation above mean sea level: 0 ft. Static level 50 ft. below top of well Date 09/18/2007 Artesian Pressure lbs per square inch Date Artesian water controlled by	
WELL TESTS: Drawdown is amount water level is lowered below static level. Was a pump test made No If yes, by whom Yield gal/min with ft drawdown after Yield gal/min with ft drawdown after Yield gal/min with ft drawdown after Recovery data (time taken as zero when pump turned off)(water level measured from well top to water level) Time: Water Level Time: Water Level Time: Water Level Date of test: Bailer test gal/min ft drawdown after hrs. Air test 12-1 gal/min w/ stem set at 179 ft. for 1 hours Artesian flow gpm Date Temperature of water Was a chemical analysis made No	

CURRENT

Notice of Intent No.: WEO7220
 Unique Ecology Well I.D. No BAT666
 Water Right Permit Number:
 OWNER: LANGSTON, RICHARD

OWNER ADD 3086-C BURNT VALLEY ROAD
 CHEWELAH, WA 99109

Well Add 2559-F UNITED COPPER MINE

City: Chewelah, WA 99109 County: Stevens
 Location: NE 1/4 NW 1/4 Sec 31 T 33 R 41E EW
 Lat/Long: Lat Deg Lat Min/Sec
 (S, E, r still
 REQUIRED) Long Deg Long Min/Sec
 Tax Parcel No.: 5610200

CONSTRUCTION OR DECOMMISSION PROCEDURE

Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

Material	From	To
CLAY BROWN	0	4
CLAY SAND GRAVEL	4	115
QUARTZITE BROWN SOFT	115	122
QUARTZITE BROWN TAN	122	130
QUARTZITE TAN GREY W/WATER	130	180

RECEIVED
 JAN 02 2008

Notes:

DEPARTMENT OF ECOLOGY
 EASTERN REGIONAL OFFICE

Work started 09/17/2007 Complete 09/18/2007

WELL CONSTRUCTION CERTIFICATION:

I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.

☒ Driller ☐ Engineer ☐ Trainee

Name: RONALD HURN License No.: 2258

Signature: *Ronald Hurn*

If trainee, Licensed driller is: License No.:

Licensed Driller Signature

Drilling Company:

NAME: FOGLE PUMP & SUPPLY, INC. Shop: COLVILLE

ADDRESS: 316 W. 5TH

Colville, WA 99115

Phone: 509-684-2569

E-Mail: jeanne@foglepump.com

FAX: 509-684-3032

WEB Site: www.foglepump.com

Contractor's

Registration No.: FOGLEPS096L4 Date Log Created: 11/06/2007