

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

WATER WELL REPORT

Start Card No. W57290  
 Unique Well I.D. # W57290 ABI 927  
 Water Right Permit No.

42307

STATE OF WASHINGTON

(1) OWNER: Name MOULDER, MARGARET Address 1021 PHILPOT RD COLVILLE, WA 99114-  
 (2) LOCATION OF WELL: County STEVENS - E 1/4 NW 1/4 Sec 20 T 39 N., R 37E WM  
 (2a) STREET ADDRESS OF WELL (or nearest address) 3019, PIERRE LAKE RD

(3) PROPOSED USE: DOMESTIC  
 (4) TYPE OF WORK: Owner's Number of well (If more than one) 1  
 Method: ROTARY  
 NEW WELL

(5) DIMENSIONS: Diameter of well 6 inches  
 Drilled 80 ft. Depth of completed well 80 ft.

(6) CONSTRUCTION DETAILS:  
 Casing installed: 6 " Dia. from +1 ft. to 80 ft.  
 WELDED " Dia. from ft. to ft.  
 " Dia. from ft. to ft.

Perforations: NO  
 Type of perforator used  
 SIZE of perforations in. by in.  
 perforations from ft. to ft.  
 perforations from ft. to ft.  
 perforations from ft. to ft.

Screens: NO  
 Manufacturer's Name  
 Type Model No.  
 Diam. slot size from ft. to ft.  
 Diam. slot size from ft. to ft.

Gravel packed: NO Size of gravel  
 Gravel placed from ft. to ft.

Surface seal: YES To what depth? 18 ft.  
 Material used in seal BENTONITE  
 Did any strata contain unusable water? NO  
 Type of water? Depth of strata ft.  
 Method of sealing strata off CASING

(7) PUMP: Manufacturer's Name  
 Type SUBMERSIBLE H.P.

(8) WATER LEVELS: Land-surface elevation above mean sea level ... ft.  
 Static level 35 ft. below top of well Date 07/17/95  
 Artesian Pressure lbs. per square inch Date  
 Artesian water controlled by CAP


(9) WELL TESTS: Drawdown is amount water level is lowered below static level.  
 Was a pump test made? NO If yes, by whom?  
 Yield: gal./min with ft. drawdown after hrs.

Recovery data  
 Time Water Level Time Water Level Time Water Level

Date of test / /  
 Bailer test gal/min. ft. drawdown after hrs.  
 Air test 40+ gal/min. w/ stem set at 78 ft. for 1 hrs.  
 Artesian flow g.p.m. Date  
 Temperature of water Was a chemical analysis made? NO

(10) WELL LOG  
 Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change in formation.

MATERIAL	FROM	TO
MEDIUM GRAVEL SAND	0	30
CEMENTED GRAVEL SAND	30	80
WATER BEARING	80	



Work started 07/14/95 Completed 07/17/95

WELL CONSTRUCTOR CERTIFICATION:  
 I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME FOGLE PUMP & SUPPLY, INC.  
 (Person, firm, or corporation) (Type or print)

ADDRESS 316 W 5TH

[SIGNED] Terry D. Corbitt License No. 1895

Contractor's Registration No. FOGLEPS095L4 Date 07/17/95