File Original and First Copy with Department of Ecology
Second Copy—Owner's Copy
Third Copy—Driller's Copy

DAX I
96889

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No. 022281

000000

Water Right Permit No.

OWNER: Name Panton, Jesse Address 619 Knob Hill Trout Ck. Rd., Republic

(2) LOCATION OF WELL: County Ferry 1st 2nd Sec T. R.
¼ ¼ ¼ Sec 2 T. 37 N., R. 32 W.M.

(2a) STREET ADDDRESS OF WELL (or nearest address) 619 Knob Hill Trout Ck. Rd., Republic 99166

(3) PROPOSED USE: ☒ Domestic ☐ Industrial ☐ Municipal
☐ Irrigation ☐ Test Well ☐ Other ☐
☐ DeWater

(4) TYPE OF WORK: Owner's number of well (if more than one) 1
Abandoned ☐ New well ☒ Method: Dug ☐ Bored ☐
Deepened ☐ Cable ☐ Driven ☐
Reconditioned ☐ Rotary ☒ Jetted ☐

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 57 feet. Depth of completed well 53 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6 " Diam. from +1 ft. to 52 ft.
Welded ☒
Liner installed ☐ " Diam. from ft. to ft.
Threaded ☐ " Diam. from No ft. to ft.

Perforations: Yes ☐ No ☒
Type of perforator used
SIZE of perforations in. by in.
perforations from ft. to ft.
perforations from ft. to ft.
perforations from ft. to ft.

Screens: Yes ☐ No ☒ No
Manufacturer's Name
Type Model No.
Diam. Slot size from ft. to ft.
Diam. Slot size from ft. to ft.

Gravel packed: Yes ☐ No ☒ Size of gravel
Gravel placed from ft. to ft.

Surface seal: Yes ☒ U No ☐ To what depth? 20 ft.
Material used in seal Bentonite
Did any strata contain unusable water? Yes ☐ No ☐
Type of water? Depth of strata
Method of sealing strata off

(7) PUMP: Manufacturer's Name
Type: H.P.

(8) WATER LEVELS: 30 Land-surface elevation above mean sea level Unknown ft.
Static level 0 ft. below top of well Date
Artesian pressure lbs. per square inch Date
Artesian water is controlled by (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes ☐ No ☒ If yes, by whom?
Yield: gal./min. with ft. drawdown after hrs.
" 7 GPM Estimated Air Lift "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test
Bailer test gal./min. with ft. drawdown after hrs.
Airtest gal./min. with stem set at ft. for hrs.
Artesian flow g.p.m. Date
Temperature of water Was a chemical analysis made? Yes ☐ No ☒

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
Overburden	0	2
Brown Sand -Coarse	2	23
Brown Sand & Gravel -Coarse	23	52
Brown Sand & Gravel	52	53
Water 7GPM		
Clay	53	57

RECEIVED
OCT - 9 1990
DEPT OF ECOLOGY
REGIONAL OFFICE

Work started 9/18/90, 19. Completed 9/19/90, 19

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME Fogle Pump & Well Drilling
(PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)

Address Po Box 147, Malo WA 99159
1238

(Signed) Richard A. Brown (LCK) Richard A. Brown
(WELL DRILLER)

Contractor's Registration No. #PS194-M Date Sep 19, 1990, 19

(USE ADDITIONAL SHEETS IF NECESSARY)

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.