

WATER WELL REPORT

State of Washington Date Printed: 28-Apr-2008 Log No. 0
 Construction / Decommission: Original Construction
 Construction Construction Notice

CURRENT
 Notice of Intent No.: WEO8163
 Unique Ecology Well I.D. No. BAE802
 Water Right Permit Number:
 OWNER: MENGUAL, AARON

| | |
|---|--|
| PROPOSED USE: DOMESTIC | |
| TYPE OF WORK: Owner's Well Number: (if more than one well) NEW WELL Method: ROTARY | |
| DIMENSIONS Diameter of well: 6 inches Drilled 96 ft. Depth of completed well 93 ft. | |
| CONSTRUCTION DETAILS: Casing installed WELDED Liner installed: 6" Dia from +3 ft. to 93 ft. " Dia from ft. to ft. " Dia from ft. to ft. " Dia from ft. to ft. | |
| Perforations: No Used in: Type of perforator used SIZE of perforations in. b in. Perforation from ft. to ft. Perforation from ft. to ft. Perforation from ft. to ft. | |
| Screens: No K-Pad Location Manufacture's Name Types: Model No Diam. slot size from ft. to ft. Diam. slot size from ft. to ft. | |
| Gravel/Filter packed: No Size of Gravel Material placed from ft. to ft. | |
| Surface seal: Yes To what depth 10 ft. Seal method: Material used in seal BENTONITE Did any strata contain unusable water No Type of water Depth of strata Method of sealing strata off | |
| PUMP: Manufacture's name Type: H.P. 0 | |
| WATER LEVELS Land-surface elevation above mean sea level: 0 ft. Static level 60 ft. below top of well Date 04/24/2008 Artesian Pressure lbs per square inch Date Artesian water controlled by | |
| WELL TESTS: Drawdown is amount water level is lowered below static level. Was a pump test made No If yes, by whom Yield [] gal/min with [] ft drawdown after [] Yield [] gal/min with [] ft drawdown after [] Yield [] gal/min with [] ft drawdown after [] Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level) Time: Water Level Time: Water Level Time: Water Level Date of test: Baller test gal/min ft drawdown after hrs. Air test 10 gal/min w/ stem set at 82 ft. for 1 hours Artesian flow gpm Date Temperature of water Was a chemical analysis made No | |

OWNER ADD P O BOX 121
 CHEWELAH, WA 99109
 Well Add 2190 HEINE ROAD
 City: Chewelah, WA 99109 County: Stevens
 Location: SE 1/4 NE 1/4 Sec 16 T 32 R 40E EW
 Lat/Long: Lat Deg Lat Min/Sec
 (S, E, R, etc) Long Deg Long Min/Sec
 REQUIRED Tax Parcel No.: 288000

CONSTRUCTION OR DECOMMISSION PROCEDURE
 Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

| Material | From | To |
|--------------------|------|----|
| BROKEN QUARTZITE | 0 | 28 |
| GRAVEL W/SAND CLAY | 28 | 74 |
| GRAVEL W/WATER | 74 | 96 |

Notes:

Work starts 04/23/2008 Complete 04/24/2008

WELL CONSTRUCTION CERTIFICATION:
 I constructed under personal responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.
 Driller Engineer Trainee

Name: ANDY BAKER License No.: 2882T
 Signature: *Andy Baker*
 License, licensed driller to: RONALD HUBB License No.: 2258
 Licensed Driller Signature: *Ronald Hubb*

Drilling Company:
 NAME: FOGLE PUMP & SUPPLY, INC. Shop: COLVILLE
 ADDRESS: 318 W. 5TH
 Colville, WA 99114
 Phone: 509-884-2659 Toll Free: 800-633-0616
 E-Mail: jeanne@foglepump.com
 FAX: 509-884-3032 WEB Site: www.foglepump.com
 Contractor's Registration No.: FOGLEPS096LA Date Log Created: 04/28/2008