

Discover tools

Unlock 75+ tools with Acrobat Pro

Start free trial

RECOMMENDED TOOL

Edit text and images
Modify or add text, images, pages and more

OTHER TOOLS

- AI Tools
 - Ask AI Assistant
 - Generate a summary
 - Create a PDF space
 - Generate Presentation
 - Generate Podcast

- Edit pages
- Organize a PDF
- Export PDF to
- E-sign
- Secure PDF

All tools

WATER WELL REPORT

State of Washington Date Printed: 06-Jun-2018 Log No. 0
 Construction / Decommission: Original Construction Notice of Intent #:
 Construction

PROPOSED USE: DOMESTIC

TYPE OF WORK: Owners's Well Number: (If more than one well) 1
 NEW WELL Method: ROTARY

DIMENSIONS: Diameter of well: 6 inches
 Drilled 180 ft. Depth of completed well 180 ft.

CONSTRUCTION DETAILS:		Casing installed		WELDED	
Liner installed: PVC		6 " Dia from	+2 ft. to	18 ft.	
4 " Dia from	8 ft. to 180 ft.	" Dia from	ft. to	ft.	
		" Dia from	ft. to	ft.	

Perforations: Yes Used In: LINER
 Type of perforator used SKILL SAW
 SIZE of perforations 1/8 in. by 7 in.
 120 Perforations from 100 ft. to 160 ft.
 Perforations from ft. to ft.
 Perforations from ft. to ft.

Screens: 0 K-Pac Location:
 Manufacture's Name
 Type: 0 Model No
 Diam. slot size: from ft. to ft.
 Diam. slot size: from ft. to ft.

Gravel/Filter packed: No Size of Gravel
 Material placed fro ft. to ft.

Surface seal: Yes To what depth 18 ft.
 Seal method: 0 Material used in seal BENT & CASING
 Did any strata contain unusable water No
 Type of water 0 Depth of strata
 Method of sealing strata off 0

PUMP: Manufacture's name
 Type: 0 H.P. 0

WATER LEVELS Land-surface elevation above mean sea level: 0 ft.
 Static level 96 ft. below top of well Date 05/22/2018
 Artesian Pressure lbs per square inch Date
 Artesian water controlled by 0

WELL TESTS: Drawdown is amount water level is lowered below static level.
 Was a pump test made No If yes, by whom
 Yield:
 Yield:
 Yield:
 Recovery da

CURRENT
 Notice of Intent No.: WE30871
 Unique Ecology Well I.D. No BKT334
 Water Right Permit Number:
 OWNER: RYAN, LEA
 OWNER ADD 2359-C HIGHWAY 25 SOUTH
 KETTLE FALLS, WA 99141
 Well Add 2359-C HIGHWAY 25 SOUTH
 City: Kettle Falls, WA 99141 County: Stevens
 Location: SW 1/4 SW 1/4 Sec 8 T 34 R 37E EW
 Lat/Long: Lat Deg Lat Min/Sec
 (s, t, r still REQUIRED) Long Deg Long Min/Se
 Tax Parcel No.: 1656951

CONSTRUCTION OR DECOMMISSION PROCEDURE
 Formation: Describe by color, character, size of material and structure. Show thickness of aquifers and the kind and nature of the material in each stratum penetrated. Show at least one entry for each change in formation.

Material	From	To
LOAM BLACK	0	3
CLAY GRAVEL BROWN	3	12
SHALE BLACK MED	12	91
SHALE BLACK SOFT	91	92
SHALE BLACK MED	92	95
SHALE BLACK SOFT DAMP	95	96
SHALE BLACK MED	96	132
SHALE BLACK SOFT DAMP	132	133
SHALE BLACK MED	133	144
SHALE BLACK SOFT WET	144	145
SHALE BLACK MED	145	180

RECEIVED
 JUN 21 2018
 Department of Ecology
 Eastern Washington Office
 Work starte 05/17/2018 Complete 05/22/2018

WELL CONSTRUCTION CERTIFICATION:
 I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported are true to my best knowledge and belief.
 Driller Engineer Trainee

Name: AUDIE MCCURDY License No.: 2690
 Signature: *Audie McCurdy*
 se No.:

Ask AI Assistant Key takeaways ... se No.: