File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

WATER WELL REPORT
STATE OF WASHINGTON

Start Card No. W95938
UNIQUE WELL I.D. # AGW 853
Water Right Permit No. _____

(1) OWNER: Name Aztec Advancements Address P.O. Box 18025 Spo.

(2) LOCATION OF WELL: County Stevens — SE ¼ SW ¼ Sec. 14 T. 29 N. R. 40 E/W

(2a) STREET ADDRESS OF WELL (or nearest address) Hwy 231

(3) PROPOSED USE: [X] Domestic [ ] Irrigation [ ] DeWater [ ] Industrial [ ] Test Well [ ] Municipal [ ] Other

(4) TYPE OF WORK: Owner's number of well (if more than one) _____
Abandoned [ ] New well [X] Deepened [ ] Reconditioned [ ]
Method: Dug [ ] Cable [ ] Rotary [X] Bored [ ] Driven [ ] Jetted [ ]

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 57 feet. Depth of completed well 54 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6" Diam. from +2 ft. to -52 ft.
Welded [X] Liner installed [ ] Threaded [ ]
" Diam. from _____ ft. to _____ ft.
" Diam. from _____ ft. to _____ ft.

Perforations: Yes [ ] No [X]
Type of perforator used _____
SIZE of perforations _____ in. by _____ in.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.
_____ perforations from _____ ft. to _____ ft.

Screens: Yes [ ] No [X]
Manufacturer's Name _____
Type _____ Model No. _____
Diam. ____ Slot size _____ from _____ ft. to _____ ft.
Diam. ____ Slot size _____ from _____ ft. to _____ ft.

Gravel packed: Yes [ ] No [X] Size of gravel _____
Gravel placed from _____ ft. to _____ ft.

Surface seal: Yes [X] No [ ] To what depth? 18 ft.
Material used in seal Redmond Min.
Did any strata contain unusable water? Yes [ ] No [X]
Type of water? _____ Depth of strata _____
Method of sealing strata off _____

(7) PUMP: Manufacturer's Name _____
Type: _____ H.P. _____

(8) WATER LEVELS: Land-surface elevation above mean sea level _____
Static level 28 ft. below top of well Date 10-15-98
Artesian pressure _____ lbs. per square inch Date _____
Artesian water is controlled by _____ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes [ ] No [ ] If yes, by whom? _____
Yield: _____ gal./min. with _____ ft. drawdown after _____ hrs.
" " " "
" " " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test _____
Bailer test ____ gal./min. with _____ ft. drawdown after _____ hrs.
Airlift 20 gal./min. with stem set at 45 ft. for 1 hrs.
Artesian flow _____ g.p.m. Date _____
Temperature of water _____ Was a chemical analysis made? Yes [ ] No [ ]

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
Top Soil	0	1
Brn Clay-Sand	1	34
Hard Pan Gravel Small	34	46
" " " Large	46	56
Blue Clay-Sand	56	57

RECEIVED NOV 17 1998 DEPARTMENT OF ECOLOGY EASTERN REGIONAL OFFICE

Work Started 10-15-98, 19. Completed 10-15, 1998

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well, and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief.

NAME B+B Drilling Inc (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)
Address 29202 N. Hwy 395
(Signed) David Allen Brown (WELL DRILLER) License No. 2048
Contractor's Registration No. 22265 Date 10-15, 1998

(USE ADDITIONAL SHEETS IF NECESSARY)

Ecology is an Equal Opportunity and Affirmative Action employer. For special accommodation needs, contact the Water Resources Program at (206) 407-6600. The TDD number is (206) 407-6006.

ECY 050-1-20 (9/93)