

Sold to
 LORI BALDWIN
 789 BARZEE ROAD
 COLVILLE, WA 99114

Ship to

<u>Account</u>	<u>P.O. Num</u>	<u>Ship Via</u>	<u>Ship Date</u>	<u>Terms</u>	<u>Invoice Date</u>	<u>Page</u>
BALDW LO	JACK	01		Net 40	7/1/13	1

<u>Item</u>	<u>Quantity</u>	<u>Description</u>	<u>Unit Price</u>	<u>Extended Price</u>
30-1236	1	GOULDS BRUIZER 10SB05 230V 2 WIRE	525.00	525.00
17-1098	1	#10/12 SPLICE KIT	5.50	5.50
30-1199	1	40/60 PRESSURE SWITCH	18.95	18.95
30-1207	1	0-100 GLYCERINE FILLED GAUGE	10.50	10.50
19-1154	1	1 1/4" X 1" GALV BELL REDUCER	2.60	2.60
Total Material and Other				562.55
30-1003	2	PUMP TECH FEE & TRAVEL Service call for no water. Replaced old pump that would not pressurize up more than 45 lbs.	150.00	300.00
30-1369	1	FUEL SURCHARGE	10.00	10.00
30-1435	1	OPERATING SUPPLIES	2.00	2.00
Total Labor				312.00

ALL INVOICES ARE DUE UPON RECEIPT.

Subtotal	874.55
Tax	66.47
Total	\$941.02

SERVICE WORK ORDER

NAME: hari BALDWIN DATE: 11-19-18

BILLING ADDRESS: 798. BARZER RD

WELL ADDRESS: _____

HM. PHONE: 680-3913 WK. PHONE: _____

WELL ID# _____

PUMP USE: DOMESTIC IRRIGATION _____ SUBDIVISION _____ RESERVOIR _____

PUMP TYPE: SUB JET _____ CENT. _____ OTHER _____

PUMP BRAND: Goulds BRUISER MODEL: 105B05

PUMP: HP 1/2 VOLTS 230 PHS MOTOR 2 WIRE

PUMP INSTALLED: DATE _____ BY _____

TANK BRAND: _____ SIZE _____ DATE INSTALLED _____

TANK LOCATION: _____

WELL: ID 6 DEPTH 35 GPM 2 OTHER _____

PITLESS _____ PIT _____ WELL HOUSE OTHER _____

IS ANYONE GOING TO BE THERE? YES NO _____

WHAT METHOD OF PAYMENT? CASH _____ CHECK CC _____ OTHER _____
IF OTHER EXPLAIN: _____

WHAT IS COMPLAINT OR SYMPTOMS?

Keeps RUNNING OUT OF WATER
WANTS TO ✓ SYSTEM SEE IF
DIAGNOSIS: ITS A WELL ISSUE

REMEDY: Jacob 11-19-18
was at job down Rd.
Stopped in to verify well
is running out of water.
Customer will figure what he wants to do.

1

SERVICE WORK ORDER

NAME: RICHARD BALDWIN DATE: 7/29/02

BILLING ADDRESS: 798 BARZEE RD. COLVILLE WA.

WELL ADDRESS: _____

WELL ID# _____ HM.PHONE: 684-7895 WK.PHONE: _____

PUMP USE: DOMESTIC IRRIGATION _____ SUBDIVISION _____ OTHER _____

PUMP TYPE: SUB JET _____ CENT. _____ OTHER _____

PUMP BRAND: Brutser MODEL: 12SB0522

PUMP: HP 1/2 VOLTS 230 PHS

PUMP INSTALLED: DATE 3/14/00 BY ICL

TANK BRAND: _____ SIZE _____ DATE INSTALLED _____

WELL: ID _____ DEPTH 56' GPM 7

PITLESS _____ PIT _____ WELL HOUSE OTHER _____

IS ANYONE GOING TO BE THERE? YES NO _____

WHAT METHOD OF PAYMENT? CASH _____ CHECK CC _____ OTHER _____

IF OTHER EXPLAIN:

WHAT IS COMPLAINT OR SYMPTONS? Need to go up TAG Bottom with pump & set BACK OFF Bottom little bit They CAN Run pump for About 10 min then NO WATER. By the pump rec. we set pump ON 20' pipe ON A seal. Need to lower

AM
Tell 1:00

DIAGNOSIS:

REMEDY: