

The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

File Original and First Copy with Department of Ecology  
Second Copy - Owner's Copy  
Third Copy - Driller's Copy

# WATER WELL REPORT

STATE OF WASHINGTON

Application No. \_\_\_\_\_  
Permit No. \_\_\_\_\_

(1) OWNER: Name ARTHUR WAGTENDOFF Address BOX 74 ADDY WASH  
(2) LOCATION OF WELL: County STEVENS - NW 1/4 RW 1/4 Sec 27 T 33 N. R 39 W.M.  
bearing and distance from section or subdivision corner

(3) PROPOSED USE: Domestic  Industrial  Municipal   
Irrigation  Test Well  Other

(4) TYPE OF WORK: Owner's number of well (if more than one) \_\_\_\_\_  
New well  Method: Dug  Bored   
Deepened  Cable  Driven   
Reconditioned  Rotary  Jetted

(5) DIMENSIONS: Diameter of well 6 inches.  
Drilled 250 ft. Depth of completed well 305 ft.

(6) CONSTRUCTION DETAILS:  
Casing installed: \_\_\_\_\_" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Threaded  \_\_\_\_\_" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Welded  \_\_\_\_\_" Diam. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Perforations: Yes  No   
Type of perforator used \_\_\_\_\_  
SIZE of perforations \_\_\_\_\_ in. by \_\_\_\_\_ in.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
\_\_\_\_\_ perforations from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Screens: Yes  No   
Manufacturer's Name \_\_\_\_\_  
Type \_\_\_\_\_ Model No \_\_\_\_\_  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Diam. \_\_\_\_\_ Slot size \_\_\_\_\_ from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Gravel packed: Yes  No  Size of gravel: \_\_\_\_\_  
Gravel placed from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.

Surface seal: Yes  No  To what depth? \_\_\_\_\_ ft.  
Material used in seal EXISTING  
Did any strata contain unusable water? Yes  No   
Type of water? \_\_\_\_\_ Depth of strata \_\_\_\_\_  
Method of sealing strata off \_\_\_\_\_

(7) PUMP: Manufacturer's Name \_\_\_\_\_  
Type: \_\_\_\_\_ H.P. \_\_\_\_\_

(8) WATER LEVELS: Land-surface elevation above mean sea level \_\_\_\_\_ ft.  
Static level \_\_\_\_\_ ft. below top of well Date \_\_\_\_\_  
Artesian pressure \_\_\_\_\_ lbs. per square inch Date \_\_\_\_\_  
Artesian water is controlled by \_\_\_\_\_ (Cap, valve, etc.)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level  
Was a pump test made? Yes  No  If yes, by whom? \_\_\_\_\_  
Yield: 1/4 gal./min with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
637 AIP LIFT

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)  
Time Water Level | Time Water Level | Time Water Level  
\_\_\_\_\_|\_\_\_\_\_|\_\_\_\_\_|\_\_\_\_\_|\_\_\_\_\_|\_\_\_\_\_|\_\_\_\_\_|\_\_\_\_\_|\_\_\_\_\_|\_\_\_\_\_|

Date of test \_\_\_\_\_  
Bailer test \_\_\_\_\_ gal./min with \_\_\_\_\_ ft. drawdown after \_\_\_\_\_ hrs.  
Artesian flow \_\_\_\_\_ g.p.m. Date \_\_\_\_\_  
Temperature of water \_\_\_\_\_ Was a chemical analysis made? Yes  No

(10) WELL LOG:  
Formation: Describe by color, character, size of material and structure, and show thickness of aquifers and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of formation.

MATERIAL	FROM	TO
<del>Shale</del>		
Shale BLACK SOFT		
WHITE STRINGERS	52	75
Shale BLACK SOFT	75	123
Shale BLACK SOFT		
WHITE STRINGERS	123	137
<del>Shale</del>		
Shale BLACK SOFT	137	240
Shale BLACK SOFT	<del>240</del>	<del>254</del>
WHITE STRINGERS	240	254
Shale BLACK SOFT	254	270
Shale BLACK SOFT		
WHITE STRINGERS	270	275
<del>Shale</del> Shale BLACK	275	305

DEEPING  
MAR 5 1986

Work started 1/30 1986 Completed 1/31 1986

WELL DRILLER'S STATEMENT:  
This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.

NAME FUGLE PUMP  
(Person, firm, or corporation) (Type or print)

Address 316 W 5th COLVILLE

[Signed] William B. Dani  
(Well Driller)

License No. 1356 Date 1/31 1986

3/5/86

(USE ADDITIONAL SHEETS IF NECESSARY)