The Department of Ecology does NOT Warranty the Data and/or the Information on this Well Report.

File Original and First Copy with Department of Ecology
Second Copy — Owner's Copy
Third Copy — Driller's Copy

59840

WATER WELL REPORT

STATE OF WASHINGTON

Start Card No W09397
UNIQUE WELL I.D. # ACT 455
Water Right Permit No. ______

OWNER: Name Jim Lapinski Address 2011 Woodland Ave E, Puyallup

(2) LOCATION OF WELL: County ~~[illegible]~~ Ferry — NE 1/4 NE 1/4 Sec 9 T. 35 N., R. 37 WM

(2a) STREET ADDRESS OF WELL (or nearest address) Somerlot SP 90-11 Lot C

(3) PROPOSED USE: [x] Domestic [ ] Irrigation [ ] DeWater — Industrial [ ] Test Well [ ] — Municipal [ ] Other [ ]

(4) TYPE OF WORK: Owner's number of well (If more than one) ______
Abandoned [ ] New well [x] Deepened [ ] Reconditioned [ ] — Method: Dug [ ] Cable [ ] Rotary [ ] Bored [ ] Driven [ ] Jetted [ ]

(5) DIMENSIONS: Diameter of well 6 inches.
Drilled 440 feet. Depth of completed well 440 ft.

(6) CONSTRUCTION DETAILS:
Casing installed: 6" Diam from +1 ft to 440 ft.
Welded [x] ___" Diam from ___ ft to ___ ft.
Liner installed [ ] ___" Diam from ___ ft to ___ ft.
Threaded [ ]

Perforations: Yes [ ] No [x]
Type of perforator used ______
SIZE of perforations ______ in by ______ in.
______ perforations from ______ ft to ______ ft.
______ perforations from ______ ft to ______ ft.
______ perforations from ______ ft to ______ ft.

Screens: Yes [ ] No [x]
Manufacturer's Name ______
Type ______ Model No ______
Diam ______ Slot size ______ from ______ ft. to ______ ft
Diam ______ Slot size ______ from ______ ft to ______ ft.

Gravel packed: Yes [ ] No [x] Size of gravel ______
Gravel placed from ______ ft to ______ ft.

Surface seal: Yes [x] No [ ] To what depth? 20 ft.
Material used in seal Bentonite
Did any strata contain unusable water? Yes [ ] No [x]
Type of water? ______ Depth of strata ______
Method of sealing strata off ______

(7) PUMP: Manufacturer's Name ______
Type ______ H.P. ______

(8) WATER LEVELS: Land-surface elevation above mean sea level ~~[illegible]~~ ft.
Static level 180 ft below top of well Date 7/5
Artesian pressure ______ lbs per square inch Date ______
Artesian water is controlled by ______ (Cap, valve etc)

(9) WELL TESTS: Drawdown is amount water level is lowered below static level
Was a pump test made? Yes [ ] No [x] If yes by whom? ______
Yield ______ gal /min with ______ ft drawdown after ______ hrs.
" " "
" " "

Recovery data (time taken as zero when pump turned off) (water level measured from well top to water level)

Time	Water Level	Time	Water Level	Time	Water Level

Date of test ______
Bailer test ______ gal /min with ______ ft drawdown after ______ hrs
Airtest 50+ gal /min with stem set at 440 ft for 1 hrs
Artesian flow ______ g p m Date ______
Temperature of water ______ Was a chemical analysis made? Yes [ ] No [x]

(10) WELL LOG or ABANDONMENT PROCEDURE DESCRIPTION

Formation Describe by color, character, size of material and structure, and show thickness of aquifer and the kind and nature of the material in each stratum penetrated, with at least one entry for each change of information.

MATERIAL	FROM	TO
Sand	0	16
Clay gray soft	16	170
Clay gray hard	170	240
Clay gray [illegible]	240	400
Clay [illegible]	400	415
Clay & sand water	415	430
Clay sand & gravel	430	439
Sand + gravel		
Bedrock Dolomite	50+ gpm	

RECEIVED
AUG - 1 2000
DEPARTMENT OF ECOLOGY
EASTERN REGIONAL OFFICE

Work Started 7/1 00 Completed 7/10 2000

WELL CONSTRUCTOR CERTIFICATION:

I constructed and/or accept responsibility for construction of this well and its compliance with all Washington well construction standards. Materials used and the information reported above are true to my best knowledge and belief

NAME Kanz Drilling (PERSON, FIRM, OR CORPORATION) (TYPE OR PRINT)
Address 5502 E Broadway
(Signed) [signature] (WELL DRILLER) License No 0257
Contractor's Registration No. DRILLC097RC Date 7/10, 2000

(USE ADDITIONAL SHEETS IF NECESSARY)

Ecology is an Equal Opportunity and Affirmative Action employer For special accommodation needs, contact the Water Resources Program at (206) 407-6600. The TDD number is (206) 407-6006.